

# **STANDARD** **OPERATING** **PROCEDURE**

Organisation: **TU Dublin - Tallaght**

Section: **School of Engineering**

Procedure Name: **Code of Conduct within Engineering Laboratory  
Electric Vehicle Development Lab (EV Lab)**  
Procedure No: **E 2092**  
Revision: **A**  
Prepared By: **Mark Murphy**  
Date: **15/05/13**  
Approved By: **James Wright**  
Date: **15/05/13**

REVISION HISTORY					
Rev	Reason for change	Effective from	Prepared date/by	Approved date/by	Description of change
A	-	Immediate	15/05/13 MM	15/05/13 JW	Initial Release

## **1.0 POLICY**

The School of Engineering provides and maintains laboratories for the purpose of supporting courses run by the School. In order to ensure a safe, learning environment, and to maintain the high standard and quality of laboratory and classroom resources, all users of School laboratories are required, at all times, to comply with the School of Engineering policy outlined below.

## **2.0 PURPOSE**

The purpose of this procedure is to outline to the Institutes staff the proper code of conduct to be observed by all users of the School of Engineering Laboratories.

## **3.0 ORGANISATIONAL UNITS AFFECTED**

All units

## **4.0 DEFINITIONS**

None

## **5.0 RESPONSIBILITY**

It is the responsibility of the Head of School and Heads of Department (Electronic and Mechanical) to ensure compliance with this procedure.

## **6.0 DESCRIPTION OF PROCEDURE**

- 6.1 Eating and/or drinking in laboratories is not permitted at any time.
- 6.2 School resources should not be used to download, distribute and/or play games, music or videos.
- 6.3 School resources must not be used to download, distribute and/or view material, likely to cause offence to others.
- 6.4 All litter must be disposed of properly in the appropriate bins provided.
- 6.5 Modification and/or repairs to laboratory equipment or computers must only be performed by ITTD technical support staff or external authorised contractors.
- 6.6 All persons using the laboratory and its resources must do so with due regard for other users and must behave in a manner that will not cause offence or disruption.
- 6.7 Laboratory resources must be used for legitimate coursework purposes and authorised activities only.

- 6.8 It is a condition of use of the laboratory, that users maintain a safe and tidy workspace. On completion of work, users must leave their workspace tidy (all equipment and accessories must be switched off and returned into storage, where applicable, and any waste material must be disposed of in the correct manner). Computer users should logout. Return chairs and any laboratory furniture to their correct positions.
- 6.9 Laboratory equipment, tools and materials must be used in a proper and responsible manner at all times. If in doubt, consult the supervising lecturer or laboratory technician.
- 6.10 Where required, users must comply with the wearing of personal protective clothing and accessories, such as safety goggles.
- 6.11 Laboratory users are obliged to immediately report to the supervising lecturer or laboratory technician, all accidents or equipment faults or damage.
- 6.14 It is a condition of use of a laboratory that all users must comply with any instructions issued by authorised ITTD staff to ensure best and safe practice within the laboratory environment.
- 6.15 It is a condition of use of the *EV Lab* that all users must comply with the standard operating procedures specified below which govern the safe use of particular laboratory resources/processes deemed to carry a risk associated with their use. These procedures are available from the technical officer responsible for the laboratory.

TBA

These procedures are available from the technical officer responsible for the laboratory.

## **7.0 REVISION OF THIS PROTOCOL**

- 7.1 Where an error, omission, or possible improvement to this protocol is identified by any member of staff, that information should be brought to the attention of the HOD / HOS as soon as possible in order that this protocol may be revised immediately.
- 7.2 This protocol will be subject to review at the end of each academic year to reflect any change in Institute, School, or Department policy or any identified error, omission, or improvement.
- 7.3 All changes will be carried out in accordance with the policy for the '*Generation of new SOPs and update and revision of existing SOPs DR001*'.

# Appendix A: Nines Laboratory Risk Assessments and Safety Information

**Note:**

This laboratory has been temporarily designated for use by Nines Photovoltaics. The attached risk assessment was conducted and supplied by Nines Photovoltaics and is presented below **Risk Assessment for Nines Photovoltaics – Lab 017A)**

**Risk Assessment/Control Data – Lab17A(Nines Photovoltaics)**

<u>Hazard/Consequence</u>	<u>Control</u>	<u>Risk Evaluation</u>	<u>Date Identified</u>	<u>Action Person</u>	<u>Date Rectified</u>
<b>Chemical Hazard</b> ADE Reactor unintentional opening. Pneumatic circuit could lose energy.	<b>Mechanical</b> The reactor is enclosed in a locked and ventilated enclosures that will detect and contain any chemical hazardous release but as an added measure ADE reactor should also be mechanically fixed in the closed position.	Unlikely x Harmful 2	20/7/2016	L Clochard	
<b>Chemical Hazard</b> At present we have no alarm on the lab room ventilation/ extraction.	<b>Mechanical control</b> Add a pressure sensor to the lab room extraction duct and connect the auxiliary contact signal back to the alarms SPC panel.	Likely x slightly harmful 2	20/7/2016	L Clochard	
<b>Pressurised gas Hazard</b> All Nitrogen/air lines used with Blow Guns should have a maximum line pressure of 30 psi.	<b>Mechanical control</b> Air regulator added to all lines used with Blow guns.	Likely x slightly harmful 2	20/06/2016	L Clochard	

<u>Ref</u>	<u>Area</u>	<u>Hazard/Consequence</u>	<u>Control</u>	<u>Risk Evaluation</u>	<u>Date Identified</u>	<u>Action Person</u>	<u>Date Rectified</u>
			systems GmbH. See Nines PV Lab 017a Lab SL2512 sign off				
	Facilities	<b>Chemical Hazard</b> Fault with gas lines/panels containing Fluorine gas.	<b>Mechanical</b> All gas lines and panels containing Fluorine gas are specially designed and installed by trained specialist teams. They enclosed in either ventilated and lock boxes or in dual wall containment tubing. All are fitted with leak containment and detection facilitates and exhausted through the emergency scrubber.  The gas containment lines are installed and commissioned by Sempu Systems and the then leak check and qualified by EST Tech Services. ... See Nines PV Lab 017a Lab SL2 Sign off	Unlikely x Harmful <sup>2</sup>	20/4/2016	Ed Duffy	22/06/2016
	Facilities	<b>Manual Handling</b> Fluorine B50 Cylinder Delivery- Shipped on a pallet.	<b>Training &amp; Wear correct PPE</b> Two Persons required, Wear Red Cotton suit provided, Safety boots, Safety Glasses, Face Shield, Nitrile Gloves with Leather Gloves over them. See _F2 Cabinet_ Nines SOPs  Pallet Lift equipment to be hired or purchased, or request that all future deliveries from Solvay, the truck has a tail-lift. <b>Mechanical control</b> Cooling exhaust of Air compressor has been	Unlikely x Harmful <sup>2</sup>	25/06/2016	L Clochard	For next delivery
	Facilities	<b>Chemical Hazard</b> The temperature within the container should		Unlikely x Slightly Harmful <sup>1</sup>	10/06/2016	L Clochard	20/07/2016

<u>Ref</u>	<u>Area</u>	<u>Hazard/Consequence</u>	<u>Control</u>	<u>Risk Evaluation</u>	<u>Date Identified</u>	<u>Action Person</u>	<u>Date Rectified</u>
		<p>be kept below 33 degrees Celsius as recommended by CS Clean for the scrubber media.</p> <p>Operational Hazard: The useful life of the scrubber media may be reduced.</p>	<p>route air recy to outside of container so that it does not add to internal heating.</p> <p>If excess temperature continues an external cladding may be needed on south facing wall of the container.</p>				
	Facilities	<b>Oxygen depletion by excess Nitrogen</b>	<p><b>O2 Sensor</b></p> <p>The Oxygen level in the container is monitored by a Honeywell sensors.</p> <p>The Honeywell sensor will alert when the sensor cell needs replacing. Also the container is ventilated constantly to reduce the impact of any gas leak or build up.</p>	Unlikely x Very Harmful 3	27/07/2016	L Clochard	27/7/2016
	Facilities	<b>Manual Handling</b>	<p><b>Training &amp; Wear correct PPE</b></p> <p>A ramp has been designed to aid the loading of cylinders. Wear slip resistant safety boots which are SRB rated. Only position the ramp outside the container on wet days when you are ready to move the trolley with cylinder into the container. The Ramp Gradient is 12 Degrees.</p>	Likely x Slightly Harmful 2	25/04/2016	Ed Duffy	25/05/2016
	Facilities	<b>Manual Handling</b>	<p><b>Training &amp; Wear correct PPE</b></p> <p>When exchanging a N2 Cylinder the ramp will be in place and this keeps the pedestrian door open and prevents the build-up of nitrogen in the container. The Hazard is the noise generated by the escaping nitrogen which effect a person's hearing. Cylinder exchange Procedure F2 Cabinet_Nines SOPs</p>	Likely x slightly harmful 2	20/06/2016	Ed Duffy	20/7/2016



Ref	Area	Hazard/Consequence	Control	Risk Evaluation	Date Identified	Action Person	Date Rectified
	Lab area 017a - Nines ADE Machine	<b>Crush Hazard</b> - Reactor opening and closing for exchanging a Conveyor belt or removing wafers or general maintenance or inspection	<b>Training &amp; Wear Correct PPE</b> Trained Engineers only allowed performing this task. A Pressure regulator is used manually to close the reactor with the pneumatic cylinders. The reactor opens under its own weight.	Unlikely x harmful 2	20/06/2016	L Clochard	20/11/2016
	Lab area 017a - Nines ADE Machine	<b>Chemical Hazard</b> Fault with gas lines/panels or process reactor containing Fluorine gas.	<b>Mechanical</b> All gas lines and panels and the ADE reactor containing fluorine gas are enclosed in ventilated and lock boxes. All are fitted with leak containment and detection facilitates and exhausted through the emergency scrubber. There are two levels of containment in the ADE tool itself and each is fitted with detection devices that shut off supply if a release is detected. This early warning/containment approach ensures that a release from the tool into the lab is highly unlikely. Testing and validation report of these and other safety interlock systems on the ADE tool See Nines PV Lab 017a Lab SL2 Sign off	Unlikely x Very Harmful 3	20/02/2016	L Clochard	20/7/2016
	Lab area 017a - Nines ADE Machine	<b>High Temperature Hazard</b> Some parts on Nines ADE machine runs at 300 Degrees Celsius.	<b>Training &amp; Wear correct PPE</b> Safety labels for the machine panels The front All hot surfaces are protected from accidental access by doors that are interlocked on the machine. Burn Cream should be made available in the First Aid Kit	Likely x slightly harmful 2	20/06/2016	Ed Duffy	20/7/2016
	Lab area 017a - Nines ADE Machine	<b>Physical Hazard, Sharp objects</b> Within the machine and while loading the cassettes silicon wafers	<b>Training &amp; Wear correct PPE</b> Suitable container/bin to be sourced for disposal/ recycling of wafers.	Likely x slightly harmful 2	20/7/2016	Ed Duffy	



<u>Ref</u>	<u>Area</u>	<u>Hazard/Consequence</u>	<u>Control</u>	<u>Risk Evaluation</u>	<u>Date Identified</u>	<u>Action Person</u>	<u>Date Rectified</u>
	Facilities	<b>Chemical Hazard</b> In the case of loss of power the electro-mechanical, exhaust fans, valves etc and PLC safety equipment may not perform as desired.	<b>Electrical</b> All safety critical system are run via a dedicated UPS system. There is also a second UPS specifically for the SEMP fluorine gas delivery system.	Unlikely x Harmful 2	1/12/15	L Clochard	20/4/16
	Facilities	<b>Chemical Hazard</b> In the event of a fan failure, the safety ventilated enclosures would be ineffective.	<b>Mechanical</b> The extraction fans system used two fan redundancy systems. Each Fan can deliver double the require extraction fro all enclosures. If one fan fails the second fan will instantly start-up.  All ventilated enclosure are constantly monitors and any loss of extraction shuts down all hazardous gas systems.	Unlikely x Harmful 2	1/12/15	L clochard	20/4/16
	Facilities	<b>Chemical Hazard</b> Fluorine -B50 Cylinder fault/leak -F2 20% N2 80% Mix	<b>Mechanical</b> The B50 cylinders are stored in a specially designed and commissioned G90 containment cabinet. The G90 cabinet is fitted with leak containment and detection facilitates. The G90 cabinet is exhausted is through an emergency gas scrubber that can pacify 1 full B50 cylinder of 20%F2 in 80% N2 gas. This system has been fully commissioned by its supplier SEMPA	Unlikely x Harmful 2	20/04/2016	Ed Duffy	22/06/2016

## FLUORINE/NITROGEN (20/80)

### SECTION 1. IDENTIFICATION OF THE SUBSTANCE/MIXTURE AND OF THE COMPANY/UNDERTAKING

#### 1.1. Product identifier

- Product name : **FLUORINE/NITROGEN (20/80)**
- Molecular formula : F<sub>2</sub>/N<sub>2</sub>
- Type of product : Mixture

#### 1.2. Relevant identified uses of the substance or mixture and uses advised against

- Identified uses :
  - Automotive industry
  - Plastic industry
  - Chemical industry
  - Electronic industry

#### 1.3. Details of the supplier of the safety data sheet

- Company : SOLVAY CHEMICALS INTERNATIONAL SA
- Address : RUE DE RANSBEEK, 310 B-1120 BRUXELLES
- Telephone : +3222642111
- Fax :
- E-mail address : [manager.sds@solvay.com](mailto:manager.sds@solvay.com)

#### 1.4. Emergency telephone number

- Emergency telephone number : **+44(0)1235 239 670 [CareChem 24] (Europe)**

### SECTION 2. HAZARDS IDENTIFICATION

#### 2.1. Classification of the substance or mixture

##### 2.1.1. European regulation (EC) 1272/2008, as amended

*Classified as hazardous according to the European regulation (EC) 1272/2008, as amended*

Hazard class	Hazard category	Route of exposure	H Phrases
Oxidising gases	Category 1		H270
Gases under pressure	Compressed gas		H280
Acute toxicity	Category 2	Inhalation	H330
Skin corrosion	Category 1A		H314

##### 2.1.2. European Directive 67/548/EEC or 1999/45/EC, as amended

*Classified as hazardous according to European Directive 67/548/EEC or 1999/45/EC, as amended*

Hazard class / Hazard category	R-phrases
O	R 7
T+	R26
C	R35

## 2.2. Label elements

### 2.2.1. Name(s) on label

Hazardous components : Fluorine (20 %)

### 2.2.2. Signal word

Danger

### 2.2.3. Hazard pictograms



### 2.2.4. Hazard statements

- H270 - May cause or intensify fire; oxidiser.
- H280 - Contains gas under pressure; may explode if heated.
- H314 - Causes severe skin burns and eye damage.
- H330 - Fatal if inhaled.

### 2.2.5. Precautionary statements

- |                   |                    |  |
|-------------------|--------------------|--|
| <b>Prevention</b> | P220               | - Keep/Store away from clothing/ flammable /combustible materials.   |
|                   | P260               | - Do not breathe dust/ fume/ gas/ mist/ vapours/ spray.  |
|                   | P280               | - Wear protective gloves/ protective clothing/ eye protection/ face protection.  |
| <b>Response</b>   | P303 + P361 + P353 | - IF ON SKIN (or hair): Remove/ Take off immediately all contaminated clothing. Rinse skin with water/ shower.                     |
|                   | P305 + P351 + P338 | - IF IN EYES: Rinse cautiously with water for several minutes. Remove contact lenses, if present and easy to do. Continue rinsing. |
|                   | P310               | - Immediately call a POISON CENTER or doctor/ physician.   |

## 2.3. Other hazards

- Chronic exposure to the product can cause bone calcification disorders.

## SECTION 3. COMPOSITION/INFORMATION ON INGREDIENTS

### 3.2 Mixtures

#### 3.2.1. Concentration

Substance name:	Concentration
<b>Fluorine</b>	ca. 20 %
CAS-No.: 7782-41-4 / EC-No.: 231-954-8 / Index-No.: 009-001-00-0	
<b>Nitrogen</b>	ca. 80 %
CAS-No.: 7727-37-9 / EC-No.: 231-783-9 / Index-No.: -	

### 3.2.2. Hazardous components - According to Regulation (EC) 1272/2008, as amended

Substance name	Hazard class	Hazard category	Route of exposure	H Phrases
<b>Fluorine</b>	Gases under pressure	Compressed gas		H280
	Oxidising gases	Category 1		H270
	Acute toxicity	Category 2	Inhalation	H330
	Skin corrosion	Category 1A		H314

### 3.2.3. Hazardous components - European Directive 67/548/EEC or 1999/45/EC, as amended

Substance name	Classification	Hazard category	R-phrase(s)
<b>Fluorine</b>	O	Oxidising	R 7
	T+	Very toxic	R26
	C	Corrosive	R35

## SECTION 4. FIRST AID MEASURES

### 4.1. Description of first aid measures

#### 4.1.1. If inhaled

- In case of accident by inhalation: remove casualty to fresh air and keep at rest.
- Oxygen or artificial respiration if needed.
- Victim to lie down in the recovery position, cover and keep him warm.
- Call a physician immediately.
- Take victim immediately to hospital.

#### 4.1.2. In case of eye contact

- Immediate medical attention is required.
- Take victim immediately to hospital.
- Rinse immediately with plenty of water, also under the eyelids, for at least 15 minutes.
- In the case of difficulty of opening the lids, administer an analgesic eye wash (oxybuprocaine).

#### 4.1.3. In case of skin contact

- Call a physician immediately.
- Take victim immediately to hospital.
- Take off contaminated clothing and shoes immediately.
- Wash off with plenty of water.
- First treatment with calcium gluconate paste.

#### 4.1.4. If swallowed

- not applicable

### 4.2. Most important symptoms and effects, both acute and delayed

#### 4.2.1. Inhalation

- Inhalation of vapours is irritating to the respiratory system, may cause throat pain and cough.
- Aspiration may cause pulmonary oedema and pneumonitis.
- risk of hypocalcemia with nervous problems (tetany) and cardiac arrhythmia
- Symptoms: Breathing difficulties, sore throat, Nose bleeding
- Repeated exposure: chronic bronchitis

#### 4.2.2. Skin contact

- Causes severe burns.
- Intoxication hazards by simultaneous inhalation of the product.
- Risk of shock.
- Risk of hypocalcemia following the extent of the lesions.
- Symptoms: Irritation, Redness, Swelling of tissue, Burn

#### 4.2.3. Eye contact

- May cause permanent eye injury.
- May cause blindness.
- Intoxication hazards by simultaneous inhalation of the product.
- Symptoms: Lachrymation, Redness, Swelling of tissue, Burn

#### 4.2.4. Ingestion

- gas
- not applicable

#### **4.3. Indication of any immediate medical attention and special treatment needed**

- HF-Antidote Gel from IPS Healthcare is recommended as treatment for injuries from hydrofluoric acid.
- If skin irritation occurs:
- Immediately apply calcium gluconate gel 2.5% and massage into the affected area using rubber gloves; continue to massage while repeatedly applying gel until 15 minutes after pain is relieved.

### **SECTION 5. FIREFIGHTING MEASURES**

#### **5.1. Extinguishing media**

##### 5.1.1. Suitable extinguishing media

- powder
- Use extinguishing measures that are appropriate to local circumstances and the surrounding environment.

##### 5.1.2. Unsuitable extinguishing media

- Never use water.

#### **5.2. Special hazards arising from the substance or mixture**

- Oxidizer
- Contact with flammables may cause fire or explosions.
- Pay attention to the spreading of gases especially at ground level (heavier than air) and to the direction of the wind.
- Contact with water liberates hazardous gas.
- Contact with water may produce heat release and presents risks of splashing.
- Hazardous decomposition products formed under fire conditions.

#### **5.3. Advice for firefighters**

- Evacuate personnel to safe areas.
- Wear self-contained breathing apparatus and protective suit.
- Wear chemical resistant oversuit
- Protect intervention team with a water spray as they approach the fire.
- Clean contaminated surface thoroughly.
- Keep product and empty container away from heat and sources of ignition.
- Cool containers / tanks with water spray.
- Keep from any possible contact with water.
- Approach from upwind.
- Never spray water onto a spillage of liquid gas.
- Never try to extinguish a burning gas leak which cannot be stopped or controlled.
- Prevent fire extinguishing water from contaminating surface water or the ground water system.

### **SECTION 6. ACCIDENTAL RELEASE MEASURES**

#### **6.1. Personal precautions, protective equipment and emergency procedures**

##### 6.1.1. Advice for non-emergency personnel

- Keep people away from and upwind of spill/leak.
- Advise people to take refuge in upper floors and in closed rooms and to wait for instructions.

#### 6.1.2. Advice for emergency responders

- Wear self-contained breathing apparatus and protective suit.
- Keep away from open flames, hot surfaces and sources of ignition.
- Approach from upwind.
- Suppress (knock down) gases/vapours/mists with a water spray jet.
- Avoid spraying the leak source.
- Try to re-position leaking containers, to have the leak in the gaseous phase.
- Ventilate the area.
- Prevent further leakage or spillage if safe to do so.
- Keep away from Incompatible products.

#### 6.2. **Environmental precautions**

- Discharge into the environment must be avoided.
- If the product contaminates rivers and lakes or drains inform respective authorities.
- Prevent product from entering drains.

#### 6.3. **Methods and materials for containment and cleaning up**

- Prevent product from entering drains.
- If possible, dam up the resulting liquid phase with sand or earth.
- Treat recovered material as described in the section "Disposal considerations".

#### 6.4. **Reference to other sections**

- Refer to protective measures listed in sections 7 and 8.

## **SECTION 7. HANDLING AND STORAGE**

### 7.1. **Precautions for safe handling**

- Carry out all operations in closed piping circuits and equipment.
- Use only in well-ventilated areas.
- Before all operations, passivate the piping circuits and vessels according to the procedure recommended by the producer.
- Clean and dry piping circuits and equipment before any operations.
- Purge piping circuits and equipment with nitrogen.
- Purge open drums with nitrogen before resealing.
- Use only equipment and materials which are compatible with the product.
- Keep away from heat and sources of ignition.
- Containers and equipment used to handle the product should be used exclusively for that product.
- Keep away from water.
- Provide piping circuits assembled by welding, or equipped with flanges using metallic gaskets compatible with the product.
- Provide shields between piping circuits or equipment and the operators; provide preferably remote operated valves.
- Provide pressure reducers at the outlet of gas cylinders.
- Do not attempt to regulate flow rate or pressure from the cylinder valve; use a suitable regulating device.
- Do not subject piping circuits or equipment to abnormal mechanical stress.
- For further information, please contact: Supplier
- Avoid inhalation, ingestion and contact with skin and eyes.
- Keep away from Organic materials.

### 7.2. **Conditions for storage, including incompatibilities**

#### 7.2.1. Storage

- Keep tightly closed in a dry, cool and well-ventilated place.
- Keep away from combustible material.
- Keep away from direct sunlight.
- Keep away from heat and sources of ignition.
- Do not store in confined space.
- Keep the cylinder cap hermetically closed and open it cautiously.



- Provide tight electrical equipment well protected against corrosion.

#### 7.2.2. Packaging material

##### 7.2.2.1. *Suitable material*

- Stainless steel cleaned and passived

##### 7.2.2.2. *Unsuitable material*

- Aluminium
- in cardboard box
- glass bottles
- Paper bags
- Plastic material, including expanded plastics material
- Woven plastic material.

#### 7.3. **Specific end use(s)**

- For further information, please contact: Supplier

### SECTION 8. EXPOSURE CONTROLS/PERSONAL PROTECTION

#### 8.1. **Control parameters**

##### 8.1.1. Exposure Limit Values

###### **Fluorine**

- Ireland. Occupational Exposure Limits 2011 time weighted average = 1 ppm  
time weighted average = 1,58 mg/m<sup>3</sup>  
Remarks: Indicative OELV
- Ireland. Occupational Exposure Limits 2011  
Short term exposure limit = 2 ppm  
Short term exposure limit = 3,16 mg/m<sup>3</sup>  
Remarks: Indicative OELV
- US. ACGIH Threshold Limit Values 03 2013 time weighted average = 1 ppm
- US. ACGIH Threshold Limit Values 03 2013 Short term exposure limit = 2 ppm
- EU. Indicative Exposure Limit Values in Directives 91/322/EEC, 2000/39/EC, 2006/15/EC, 2009/161/EU 12 2009  
time weighted average = 1 ppm  
time weighted average = 1,58 mg/m<sup>3</sup>  
Remarks: Indicative
- EU. Indicative Exposure Limit Values in Directives 91/322/EEC, 2000/39/EC, 2006/15/EC, 2009/161/EU 12 2009  
Short term exposure limit = 2 ppm  
Short term exposure limit = 3,16 mg/m<sup>3</sup>  
Remarks: Indicative

###### **Nitrogen**

- Ireland. Occupational Exposure Limits 2011  
Remarks: Included in the regulation but with no data values. See regulation for further details.
- US. ACGIH Threshold Limit Values 03 2013  
Remarks: Included in the regulation but with no data values. See regulation for further details.

#### 8.2. **Exposure controls**

##### 8.2.1. Appropriate engineering controls

- Use only with adequate ventilation and in closed systems.
- Apply technical measures to comply with the occupational exposure limits.
- Detection of small leaks using ammonia or preferably KI (potassium iodide) - papers or qualified leak detectors

## 8.2.2. Individual protection measures

### 8.2.2.1. *Respiratory protection*

- Self-contained breathing apparatus in confined spaces/insufficient oxygen/in case of large uncontrolled emissions/in all circumstances when the mask and cartridge do not give adequate protection.
- Use only respiratory protection that conforms to international/ national standards.
- Respirator with a full face mask
- Recommended Filter type: B

### 8.2.2.2. *Hand protection*

- Wear suitable gloves.
- Suitable material: Copolymer VF2-HFP (fluoroelastomer)

### 8.2.2.3. *Eye protection*

- Chemical resistant goggles must be worn.

### 8.2.2.4. *Skin and body protection*

- Complete suit protecting against chemicals
- impervious clothing

### 8.2.2.5. *Hygiene measures*

- Eye wash bottles or eye wash stations in compliance with applicable standards.
- Handle in accordance with good industrial hygiene and safety practice.
- Consult the industrial hygienist or the safety manager for the selection of personal protective equipment suitable for the working conditions.

## 8.2.3. Environmental exposure controls

- Dispose of rinse water in accordance with local and national regulations.

## SECTION 9. PHYSICAL AND CHEMICAL PROPERTIES

### 9.1. Information on basic physical and chemical properties

#### 9.1.1. General Information

<input type="checkbox"/> <b>Appearance</b>	Compressed gas
<input type="checkbox"/> <b>Colour</b>	colourless
<input type="checkbox"/> <b>Odour</b>	pungent

#### 9.1.2. Important health safety and environmental information

<input type="checkbox"/> <b>pH</b>	not applicable
<input type="checkbox"/> <b>pKa</b>	not applicable
<input type="checkbox"/> <b>Melting point/freezing point</b>	-220 °C (Fluorine)
<input type="checkbox"/> <b>Boiling point/boiling range</b>	-188 °C (Fluorine)
<input type="checkbox"/> <b>Flash point</b>	not applicable
<input type="checkbox"/> <b>Evaporation rate</b>	No data
<input type="checkbox"/> <b>Flammability (solid, gas)</b>	The product is not flammable.
<input type="checkbox"/> <b>Flammability</b>	not applicable
<input type="checkbox"/> <b>Explosive properties</b>	See section 10.
<input type="checkbox"/> <b>Vapour pressure</b>	1.013 mbar, at -188 °C
<input type="checkbox"/> <b>Vapour density</b>	1,3 (Fluorine)
<input type="checkbox"/> <b>Density</b>	No data
<input type="checkbox"/> <b>Relative density</b>	1,51, at -188 °C (Fluorine)
<input type="checkbox"/> <b>Bulk density</b>	not applicable

☐ Solubility(ies)	not applicable
☐ Solubility/qualitative	Decomposes in contact with water.
☐ Partition coefficient: n-octanol/water	not applicable
☐ Auto-ignition temperature	No data
☐ Decomposition temperature	No data
☐ Viscosity	1.013 mPa.s, at 25 °C (Fluorine)
☐ Oxidizing properties	Oxidizing properties

## 9.2. Other information

☐ Critical temperature	-129,2 °C (Fluorine)
☐ Critical pressure	55,72 hPa (Fluorine)

## SECTION 10. STABILITY AND REACTIVITY

### 10.1. Reactivity

- Risk of ignition.
- Risk of explosion.
- Reacts violently with water.

### 10.2. Chemical stability

- Chemically very reactive
- Stable under recommended storage conditions.

### 10.3. Possibility of hazardous reactions

- Decomposes in contact with water.
- Fire or intense heat may cause violent rupture of packages.
- Heating can release hazardous gases.
- Gives off hydrogen by reaction with metals.

### 10.4. Conditions to avoid

- Heat.
- Exposure to moisture.

### 10.5. Incompatible materials

- Organic materials, Flammable materials, Combustible material, Hydrogen

### 10.6. Hazardous decomposition products

- Hydrogen fluoride

## SECTION 11. TOXICOLOGICAL INFORMATION

### 11.1. Acute toxicity

#### 11.1.1. Acute inhalation toxicity

- LC50, 1 h, rat , 925 ppm, calculated value

#### 11.1.2. Irritation (other route)

- Inhalation, rat, Corrosive (Fluorine)

### 11.2. Skin corrosion/irritation

- Corrosive (Fluorine)

### 11.3. Serious eye damage/eye irritation

- Corrosive (Fluorine)

### 11.4. Sensitisation

- no data available

### 11.5. Mutagenicity

- no data available

### 11.6. Carcinogenicity

- The carcinogenic effect found in animals is not demonstrated in human (Fluorine)

### 11.7. Toxicity for reproduction

- Risk of toxic effect on reproduction (Fluorine)

### 11.8. Repeated dose toxicity

- Inhalation, Prolonged exposure, rat, Target Organs: Respiratory system, Central nervous system, Cardio-vascular system, testes, Kidney, Liver, observed effect (Hydrogenfluoride)

### 11.9. Other information

- no data available

## SECTION 12. ECOLOGICAL INFORMATION

### 12.1. Toxicity

- Fishes, *Salmo gairdneri*, LC50, 96 h, 51 mg/l (Fluorides)
- Crustaceans, *Daphnia magna*, EC50, 48 h, 97 mg/l, fresh water (Fluorides)
- Crustaceans, *Mysidopsis bahia*, EC50, 96 h, 10,5 mg/l, salt water (Fluorides)
- Fishes, *Salmo gairdneri*, LC50, 21 Days, from 2,7 - 4,7 mg/l (Fluorides)
- Crustaceans, *Daphnia magna*, NOEC, 21 Days, 3,7 mg/l (Fluorides)
- Algae, *Scenedesmus sp.*, EC50, 96 h, 43 mg/l (Fluorides)

### 12.2. Persistence and degradability

#### 12.2.1. Abiotic degradation

- Water, Soil  
Result: complexation/precipitation of inorganic materials (Fluorides)
- Water, Soil Result:  
hydrolyses  
Degradation products: hydrofluoric acid / fluoride (Fluorine)

#### 12.2.2. Biodegradation

- The methods for determining biodegradability are not applicable to inorganic substances. (Fluorine)

### 12.3. Bioaccumulative potential

- Result: The methods for determining the biological degradability are not applicable to inorganic substances. (Fluorine)

### 12.4. Mobility in soil

- Reacts violently with water. (Fluorine)

### 12.5. Results of PBT and vPvB assessment

- no data available

### 12.6. Other adverse effects

- no data available

## SECTION 13. DISPOSAL CONSIDERATIONS

### 13.1. Waste treatment methods

- Refer to manufacturer/supplier for information on recovery/recycling.
- or
- Absorb the product in a KOH solution.
- Filtrate the product and send the cake to a landfill for industrial waste.
- Discharge liquid filtrate to a wastewater treatment system

### 13.2. Contaminated packaging

- To avoid treatments, as far as possible, use dedicated containers.
- Do not rinse the dedicated containers.

## SECTION 14. TRANSPORT INFORMATION

### International transport regulations

#### - IATA-DGR

14.1. UN number	UN 3306
14.2. UN proper shipping name	COMPRESSED GAS, TOXIC, OXIDIZING, CORROSIVE, N.O.S.(FLUORINE/NITROGEN MIXTURE 20/80)
14.3. Transport hazard class(es)	
Hazard class	FORBIDDEN
Labels	2.3 - Toxic gas 5.1 - Oxidizing substances 8 - Corrosive
14.4. Packing group	
14.5. Environmental hazards	
14.6. Special precautions for user	

#### - IMDG

14.1. UN number	UN 3306
14.2. UN proper shipping name	COMPRESSED GAS, TOXIC, OXIDIZING, CORROSIVE, N.O.S.(FLUORINE/NITROGEN MIXTURE 20/80)
14.3. Transport hazard class(es)	
Hazard class	2.3
Labels	2.3 - Toxic gasses 5.1 - Oxidizing substances 8 - Corrosive
14.4. Packing group	
14.5. Environmental hazards	
14.6. Special precautions for user	
EmS	F-C S-W

#### - ADR

14.1. UN number	UN 3306
14.2. UN proper shipping name	COMPRESSED GAS, TOXIC, OXIDIZING, CORROSIVE, N.O.S.(FLUORINE/NITROGEN MIXTURE 20/80)

14.3. Transport hazard class(es)	
Hazard class	2
Labels	2.3 - Toxic gas 5.1 - Oxidizing substances 8 - Corrosive
14.4. Packing group	
14.5. Environmental hazards	
14.6. Special precautions for user	
HI/UN No.	265 / 3306
Tunnel restriction code	C/D
<b>- RID</b>	
14.1. UN number	UN 3306
14.2. UN proper shipping name	COMPRESSED GAS, TOXIC, OXIDIZING, CORROSIVE, N.O.S.(FLUORINE/NITROGEN MIXTURE 20/80)
14.3. Transport hazard class(es)	
Hazard class	2
Labels	2.3 - Toxic gas 5.1 - Oxidizing substances 8 - Corrosive
14.4. Packing group	
14.5. Environmental hazards	
14.6. Special precautions for user	
HI/UN No.	265 / 3306
<b>- ADN</b>	
14.1. UN number	UN 3306
14.2. UN proper shipping name	COMPRESSED GAS, TOXIC, OXIDIZING, CORROSIVE, N.O.S.(FLUORINE/NITROGEN MIXTURE 20/80)
14.3. Transport hazard class(es)	
Hazard class	2
Labels	2.3 - Toxic gas 5.1 - Oxidizing substances 8 - Corrosive
14.4. Packing group	
14.5. Environmental hazards	
14.6. Special precautions for user	

## SECTION 15. REGULATORY INFORMATION

### 15.1. Safety, health and environmental regulations/legislation specific for the substance or mixture

- Regulation (EC) No 1907/2006 of the European Parliament and of the Council of 18 December 2006 concerning the Registration, Evaluation, Authorisation and Restriction of Chemicals (REACH), as amended
- Directive 1999/45/EC of the European Parliament and of the Council of 31 May 1999 concerning the approximation of the laws, regulations and administrative provisions of the Member States relating to the classification, packaging and labelling of dangerous preparations, as amended
- Regulation (EC) No 1272/2008 of the European Parliament and of the Council of 16 December 2008 on classification, labelling and packaging of substances and mixtures, as amended



- Council Directive 98/24/EC of 7 April 1998 on the protection of the health and safety of workers from the risks related to chemical agents at work, as amended
- COUNCIL DIRECTIVE 96/82/EC on the control of major-accident hazards involving dangerous substances as amended
- Directive 2008/98/EC of the European Parliament and of the Council of 19 November 2008 on waste
- 1999 Code of Practice for the Safety, Health and Welfare at Work (Chemicals Agents) Regulations, 1994 (S.I. No. 445 of 1994) as amended

#### 15.1.1. Notification status

Inventory Information	Status
Australia. Inventory of Chemical Substances (AICS)	- In compliance with inventory
Canada. Domestic Substances List (DSL)	- In compliance with inventory
China. Inventory of Existing Chemical Substances (IECSC)	- In compliance with inventory
Japan (ENCS) List (ENCS (JP))	- All ingredients are on the following inventories or are exempted from listing
New Zealand. Inventory of Chemicals (NZIOC)	- In compliance with inventory
USA. Toxic Substances Control Act (TSCA)	- In compliance with inventory
EU list of existing chemical substances (EINECS)	- In compliance with inventory
Korea. Existing Chemicals Inventory (KECI (KR))	- In compliance with inventory
Philippines PICCS (PICCS (PH))	- In compliance with inventory
Mexico INSQ (INSQ)	- In compliance with inventory

#### 15.2. Chemical Safety Assessment

- no data available

### SECTION 16. OTHER INFORMATION

#### 16.1. Full text of H-Statements referred to under section 3

- |      |   |
|------|---|
| H270 | - May cause or intensify fire; oxidiser.              |
| H280 | - Contains gas under pressure; may explode if heated. |
| H314 | - Causes severe skin burns and eye damage.            |
| H330 | - Fatal if inhaled.                                   |

#### 16.2. Full text of R-phrases referred to under sections 2 and 3

##### 16.2.1. Full text of R-phrases referred to under section 2 R 7

- |     |                             |
|-----|-----------------------------|
| R26 | - May cause fire.           |
| R35 | - Very toxic by inhalation. |
| R35 | - Causes severe burns.      |

##### 16.2.2. Full text of R-phrases referred to under section 3 R 7

- |     |                             |
|-----|-----------------------------|
| R26 | - May cause fire.           |
| R35 | - Very toxic by inhalation. |
| R35 | - Causes severe burns.      |

#### 16.3. Other information

- Update  
This data sheet contains changes from the previous version in section(s): 1.3,5,3,6,7,8,14,15.1.1

This SDS is only intended for the indicated country to which it is applicable. The European SDS format compliant with the applicable European legislation is not intended for use nor distribution in countries outside the European Union with the exception of Norway and Switzerland. Safety datasheets applicable in other countries/regions are available upon request.

The information given corresponds to the current state of our knowledge and experience of the product, and is not exhaustive. This applies to product which conforms to the specification, unless otherwise stated. In this case of combinations and mixtures one must make sure that no new dangers can arise. In any case, the user is not exempt from observing all legal, administrative and regulatory procedures relating to the product, personal hygiene, and protection of human welfare and the environment.

## 5.13.2. Commissioning Sign-Off



### FINAL SIGN OFF

Final HAZOP risk assessment of the full installation

Appendix 12 ITT / Nines \_\_\_\_\_ Date \_\_\_\_\_

Acceptance by insurance underwriters

Appendix 13 ITT / Nines \_\_\_\_\_ Date \_\_\_\_\_

# Service Report

40124354

ORIGINAL

Date of Service	05-25-2016	Life Safety Distribution GmbH
Customer PO	PO 000775	Javastrasse 2
Customer Contact	Laurent Clochard	8604 Hegnau Switzerland

<b>Bill To</b>	<b>Sold To</b>
Nines PV Finance Dept Synergy Center D24FKT9 Dublin IE	Ultra High Vacuum Solutions Li 37 Rathfarnham Gate Dublin D14 AY88 IE

<b>Order Information</b>	<b>Ship To</b>
Internal Reference: 50767772 Service Type: Field Honeywell Location: Ireland Local Honeywell Contact Payment Terms: Advance payment Project Name: IT Tallaght Commissioning	Nines PV Synergy Centre Dublin D24FKT9 IE

ITEM NO.	PART NUMBER	DESCRIPTION	QUANTITY	UNIT OF MEASURE	UNIT PRICE	EXT. PRICE
----------	-------------	-------------	----------	-----------------	------------	------------

10	SERVICE_RATE_1	Commissioning	1.000	AU	0.00	0.00
----	----------------	---------------	-------	----	------	------

Completed commissioning on the following F2 detection units:  
 Sat Serial Number: 0216102(EN CAT 002)  
 Sat Serial Number: 0216101(EN CAT 001)  
 Midas Serial Number: V16020117(EN CAT 004)

All above units are mounted on the tool and their outputs feed back to the tool PLC.  
 Connected up the Sat units to the ducts. Installed sensors, Set A1,A2 at 0.1ppm. Set relays at NO/Denergised.  
 We did not verify output operation to tool as tool was not up and running.

Did commissioning on midas. Installed F2 cartridge. Set the ma o/p as follows:  
 Midas source, jumpered as INT J4 and out on pin 10 to PLC with return on pin 9 jumpered to EXT on J5.  
 Set relays as NO/Denergised. Set the A1,A2 to 0.48 ppm as the LAL is 0.48 could not set to 0.1ppm as requested.

Installed batteries in TP4 unit. Connected 2 12 vdc in series to give 24 vdc as supplied by Laurent, I verified operation by switching off 220 vac to unit, and power supply kicked in with no issue.  
 The fault on the TP4 unit common module was due to a bad connection internally on the common module card. I reseated this and fault cleared with no issue. Panel was clear and in monitoring on leaving.

To Do: Sample point tubing will need to be mounted on tool to monitoring point and exhaust tubing will need to be ran to scrub exhaust  
 All 3 units outputs will need cause/effect verification to tool PLC when up and running.

Registered No	CH-020.3.925.850-0	Federal ID	Duns
---------------	--------------------	------------	------

HA IE Service Team Ireland	Customer Service Team
----------------------------	-----------------------

Certified that the whole of the supplies/services detailed in this consignment have been inspected and tested in accordance with the conditions and requirements of the contract or purchase order and unless otherwise stated conform in all respects to the specification(s), drawing(s) relevant thereto.

On Behalf of Honeywell	On Behalf of Customer
Print	Print

Additional Comments

2nd day of commissioning, 1st day linked to SO 40110649

Sub Totals

Materials	0.00	
Labour	0.00	
Travel & Expenses	0.00	
Shipping Charge	0.00	
<b>TOTAL</b>	<b>0.00</b>	<b>EUR</b>

All prices stated above are net prices and are subject to VAT where applicable and will be billed accordingly with the appropriate VAT rate at the time of shipment.

Registered No	CH-020.3.925.850-0	Federal ID	Duns
HA IE Service Team	Ireland	Customer Service Team	
Service Team Leader			
Certified that the whole of the supplies/services detailed in this consignment have been inspected and tested in accordance with the conditions and requirements of the contract or purchase order and unless otherwise stated conform in all respects to the specification(s), drawing(s) relevant thereto.			
On Behalf of Honeywell		On Behalf of Customer	
Print		Print	



# Service Report

40119074

ORIGINAL

Date of Service	03-18-2016	Life Safety Distribution GmbH
Customer PO	000775	Javastrasse 2
Customer Contact	Laurent Clochard	8604 Hegnau Switzerland

<b>Bill To</b>	<b>Sold To</b>
Nines PV Finance Dept Synergy Center D24FKT9 Dublin IE	Ultra High Vacuum Solutions Li 37 Rathfarnham Gate Dublin D14 AY88 IE

<b>Order Information</b>	<b>Ship To</b>
Internal Reference: 50715830 Service Type: Field Honeywell Location: Ireland Local Honeywell Contact: Payment Terms: Advance payment Project Name: IT Tallaght Project	Nines PV Synergy Centre Dublin D24FKT9 IE

ITEM NO.	PART NUMBER	DESCRIPTION	QUANTITY	UNIT OF MEASURE
----------	-------------	-------------	----------	-----------------

10	SERVICE_RATE_1	Commissioning	1.000	AU
----	----------------	---------------	-------	----

**Additional Comments**

Completed Commissioning and start up on the following unit:  
 TP4 Serial Number: C08260113. Outputs to horn/strobes wired in through the relays at points 4 and 5 NC  
 Sat F2 Serial No: 0815113, QS 040 located on pole in Lab sampling ambient. The 4-20 ma o/p from this unit is connected to Channel 2 on TP4. Alarm level 1 and 2 set to 0.1 with full scale at 5. TP4 set up the same. The relays are set up as A1 and A2 energized NC. The fault relay set up as de energized NO.  
 Sat F2 Serial No: 0815110, Q 20 located on wall in container sampling ambient. The 4-20 ma o/p from this unit is connected to Channel 2 on TP4. Alarm level 1 and 2 set to 0.1 with full scale at 5. TP4 set up the same. The relays are set up as A1 and A2 energized NC. The fault relay set up as de energized NO.  
 Signal point O2 Serial No 719161709, O2 No 2 located on wall in Lab sampling ambient. The 4-20 ma loop on this unit is connected to Channel 3 on TP4. Alarm level 1 and 2 set to 19.5% v/v with full scale at 25% on TP4  
 Signal point O2 Serial No 719343709, O2 No 1 located on wall in container sampling ambient. The 4-20 ma loop on this unit is connected to Channel 4 on TP4. Alarm level 1 and 2 set to 19.5% v/v with full scale at 25% on TP4.  
 All four units above had their sensors replaced and were zeroed. For F2 units I forced the 4-20 ma and verified A1 and A2 activation on TP4. From this the O/P's from the TP4 activated the horns/strobes as scheduled. The relay O/P's were also verified to the Nines panel and all were activating as required.  
 For the O2 units the O2 was depleted on the sensors and horn/strobe activation verified.  
 The following units that will not be connected to the TP4 panel were also set up:  
 Sat F2 Serial No: 0815112, QS 030 located on wall in Lab for tool duct. Alarm level 1 and 2 set to 0.1 with full scale at 5. The relays are set up as A1 and A2 energized NC. The fault relay set up as de energized NO. Verified the A1 A2 and Fault relay o/p to Nines panel and all good  
 Sat F2 Serial No: 0815111, Q 10 located on wall in container for tool

Registered No	CH-020.3.925.850-0	Federal ID	Duns
HA IE Service Team	Ireland	Service Team Leader	Customer Service Team
Certified that the whole of the supplies/services detailed in this consignment have been inspected and tested in accordance with the conditions and requirements of the contract or purchase order and unless otherwise stated conform in all respects to the specification(s), drawing(s) relevant thereto.			
On Behalf of Honeywell		On Behalf of Customer	
Print		Print	

duct. Alarm level 1 and 2 set to 0.1 with full scale at 5. The relays are set up as A1 and A2 energized NC. The fault relay set up as de energized NO. Verified the A1 A2 and Fault relay o/p to Nines panel and all good  
All units had up to date cal stickers installed.

All prices stated above are net prices and are subject to VAT where applicable and will be billed accordingly with the appropriate VAT rate at the time of shipment.

Registered No	CH-020.3.925.850-0	Federal ID	Duns
HA IE Service Team	Ireland	Customer Service Team	
Service Team Leader			
Certified that the whole of the supplies/services detailed in this consignment have been inspected and tested in accordance with the conditions and requirements of the contract or purchase order and unless otherwise stated conform in all respects to the specification(s), drawing(s) relevant thereto.			
On Behalf of Honeywell		On Behalf of Customer	
Print		Print	





# CLEANVENT DATA SHEET

Fraunhoferstrasse 4  
85737 Ismaning  
Germany  
Phone: +49 (89) 96 24 00-0  
Fax: +49 (89) 96 24 00-122  
sales@csclean.com  
www.csclean.com



<b>CLEANVENT Type / Serial No.</b>	CV02S / CV02S15011
<b>Filling Code</b>	FC 9577
<b>Filling suitable for gas species*</b>	F2 (N <sub>2</sub> , H <sub>2</sub> )
<b>Capacity</b>	120 standard litres
<b>Outlet Concentration</b>	
<b>Intended use</b>	Passive dry-bed absorber for removal of hazardous vent gases
<b>Construction material</b>	316 / 316L stainless steel
<b>Construction features</b>	Overall length 400 mm, outside diameter 114 mm, 1/4" VCR compatible fittings at inlet and outlet
<b>Environmental temperature range</b>	5-35 °C (40-95 °F) (please contact manufacturer if different temperature range required)
<b>Installation site</b>	indoors
<b>Operation pressure</b>	≤ 1 MPa (145 psi)
<b>Emergency relief valve</b>	fitted
<b>Wallmounting included</b>	yes
<b>Inlet flow restrictor</b>	internal
<b>Weight</b>	Approx. 8 kg
<b>Month of expiry</b>	05/2017
<b>Leak test passed</b>	Date: 18.05.2015, Operator: <i>[Signature]</i>
<b>Functional test passed</b>	Date: 18.05.2015, Operator: <i>[Signature]</i>

\* Gases listed in (brackets) are permitted, but not retained by the cartridge.

*Before installing the CLEANVENT cartridge please ensure that you have read the operating manual.*



**Ultra High Purity Pressure Transducer  
Production Test Report**

Transducer #	M4141	Serial #	5125632
Model	WU 10	Ambient Temperature	19.0 °C
Pressure Range	-1 - 200 bar	Power Supply	24 V DC
Output Signal	4 - 20 mA	Test Date	02.05.2007

Pressure bar	Signal (increasing pressure) mA	Signal (decreasing pressure) mA	Error (increasing pressure) %	Error (decreasing pressure) %
-1.00	4.004	3.995	0.026	-0.034
0.00	4.075	4.070	-0.029	-0.060
89.50	11.992	11.984	-0.053	-0.101
200.00	19.993	19.986	-0.045	-0.090

<b>Maximal Error in % FS</b>	<b>-0.101</b>
<b>Non-Linearity in % FS</b>	<b>-0.041</b>
<b>Particles</b>	<b>&lt; 0.1 per ft<sup>3</sup> &gt; 0.1 nm</b>
<b>Helium Leakrate</b>	<b>&lt; 1* 10<sup>-8</sup> mbar l/s / atm cm<sup>2</sup>/s</b>

WIKAI Alexander Wiegand GmbH & Co. KG  
Alexander-Wiegand-Strasse 63911 Klingenberg  
Phone +49-9372 / 132-0 Fax +49-9372 / 132-408  
http://www.wika.de E-mail: info@wika.de  
http://www.wika.com

  
\_\_\_\_\_  
(signed)



## Ultra High Purity Pressure Transducer Production Test Report

Transducer #	M4015	Serial #	5125634
Model	WU 10	Ambient Temperature	19.0 °C
Pressure Range	-1 - 200 bar	Power Supply	24 V DC
Output Signal	4 - 20 mA	Test Date	02.05.2007

Pressure bar	Signal (increasing pressure) mA	Signal (decreasing pressure) mA	Error (increasing pressure) %	Error (decreasing pressure) %
-1.00	4.005	3.990	0.033	-0.065
0.00	4.084	4.068	0.028	-0.073
99.50	12.008	11.999	0.050	-0.005
200.00	20.022	20.021	0.135	0.133

Maximal Error in % FS	0.135
Non-Linearity in % FS	-0.037
Particles	< 0.1 per ft <sup>3</sup> > 0.1 nm
Helium Leakrate	< 1* 10 <sup>-9</sup> mbar l/s / atm cm <sup>2</sup> /s

WIKAI Alexander Wiegand GmbH & Co. KG  
Alexander-Wiegand-Strasse 63811 Klingenberg  
Phone +49-9372/132-0 Fax +49-9372/132-408  
<http://www.wika.de> E-mail: [info@wika.de](mailto:info@wika.de)  
<http://www.wika.com>

  
(signed)



## Ultra High Purity Pressure Transducer Production Test Report

Transducer #	N4400	Serial #	06983909
Model	WU 10	Ambient Temperature	19.0 °C
Pressure Range	-1 - 9 bar	Power Supply	24 V DC
Output Signal	4 - 20 mA	Test Date	22.05.2015

Pressure bar	Signal (Increasing pressure) mA	Signal (decreasing pressure) mA	Error (increasing pressure) %	Error (decreasing pressure) %
-1.00	3.989	3.978	-0.066	-0.138
0.00	5.590	5.590	-0.060	-0.064
4.00	12.000	11.988	0.001	-0.077
9.00	20.001	19.998	0.008	-0.010

**Maximal Error in % FS** -0.138  
**Non-Linearity in % FS** 0.030  
**Particles** < 0.1 per ft<sup>3</sup> > 0.1 nm  
**Helium Leakrate** < 1\* 10<sup>-9</sup> mbar l/s /  
atm cm<sup>2</sup>/s

WIKAI Alexander Wiegand SE & Co. KG  
Alexander-Wiegand-Strasse 63911 Klingenberg  
Phone +49-9372 / 132-0 Fax +49-9372 / 132-408  
http://www.wika.de E-mail: info@wika.de  
http://www.wika.com

*Mollath 2015*  
(signed)





# Ultra High Purity Pressure Transducer Production Test Report

Transducer #	N4383	Serial #	06983908
Model	WU 10	Ambient Temperature	19.0 °C
Pressure Range	-1 - 9 bar	Power Supply	24 V DC
Output Signal	4 - 20 mA	Test Date	22.05.2015

Pressure bar	Signal (increasing pressure) mA	Signal (decreasing pressure) mA	Error (increasing pressure) %	Error (decreasing pressure) %
-1.00	3.995	3.988	-0.034	-0.072
0.00	5.593	5.593	-0.046	-0.043
4.00	11.999	11.991	-0.009	-0.057
9.00	20.003	20.004	0.017	0.025

Maximal Error in % FS	-0.072
Non-Linearity in % FS	-0.017
Particles	< 0.1 per ft <sup>3</sup> > 0.1 nm
Helium Leakrate	< 1* 10 <sup>-9</sup> mbar l/s / atm cm <sup>2</sup> /s

WIKAI Alexander Wiegand SE & Co. KG  
Alexander-Wiegand-Strasse 63911 Klingenberg  
Phone +49-9372 / 132-0 Fax +49-9372 / 132-400  
<http://www.wika.de> E-mail: [info@wika.de](mailto:info@wika.de)  
<http://www.wika.com>

*Alexander Wiegand*  
(signed)




**Ultra High Purity Pressure Transducer  
Production Test Report**

Transducer #	N4307	Serial #	06983910
Model	WU 10	Ambient Temperature	19.0 °C
Pressure Range	-1 - 9 bar	Power Supply	24 V DC
Output Signal	4 - 20 mA	Test Date	22.05.2015

Pressure bar	Signal (increasing pressure) mA	Signal (decreasing pressure) mA	Error (increasing pressure) %	Error (decreasing pressure) %
-1.00	3.998	3.982	-0.024	-0.110
0.00	5.604	5.588	0.026	-0.075
4.00	12.002	11.998	0.014	-0.027
9.00	20.010	20.011	0.062	0.066

**Maximal Error in % FS**                      -0.110  
**Non-Linearity in % FS**                      0.030  
**Particles**    < 0.1 per ft<sup>3</sup> > 0.1 nm  
**Helium Leakrate**                                      < 1\* 10<sup>-8</sup> mbar l/s / atm cm<sup>2</sup>/s

WIKAI Alexander Wiegand SE & Co. KG  
Alexander-Wiegand-Strasse 63911 Klingenberg  
Phone +49-9372 / 132-0 Fax +49-9372 / 132-408  
http://www.wika.de E-mail: info@wika.de  
http://www.wika.com

  
(signed)





Industrie Service

1 **SCHWEISSER-PRÜFUNGSBESCHEINIGUNG / ZERTIFIKAT**

2 Bezeichnung **EN 287-1 141 T BW 8 S t1.0 D12 H-L045 ss nb**  
 4 Hersteller-Schweißanweisung Teiln.-Nr.: 8453  
 5 Beleg-Nr. (falls verfügbar): P9349 Zertifikat Nr.: Z-IS-DD1-DRE-13-12-2379031-10094010  
 6 Name des Schweißers: **Uhlig, Giselher**  
 8 Art der Legitimation: Personalausweis  
 9 Geburtsdatum und Ort: 07.06.1965 Dresden  
 10 Beschäftigt bei: Sempa Systems GmbH, Dresden  
 11 Vorschrift / Prüfnorm: EN 287-1 und AD 2000 HP3  
 Bemerkung:



12 Fachkunde **bestanden**

13	Prüfdaten - Angaben	Geltungsbereich
14 Schweißprozesse	141 (WIG) Wolfram-Inertgas (Massivstab)	141, 142, 143, 145
15 Produktform (Blech/Rohr)	T (Rohr)	T, P
16 Nahtart	BW (Stumpfnah)	BW
17 Werkstoffgruppe(n)	8 (X2CrNiMo18-14-3 (1.4435))	8, 10 (9.2, 9.3 mit SZW Gruppe 8, 10)
18 Art des Zusatzwerkstoffes	Massivstab (S)	S (Massivstab), nm (ohne Zusatz)
Bezeichnung	EN 12072: W 19 12 3 L Si	
19 Schutzgas / Pulver	EN ISO 14175 - I1	geeignete Schutzgase
20 Hilfsstoffe	Formiergas	—
21 Werkstoffdicke (mm)	1	1 - 2
22 Rohrdurchmesser (außen)(mm)	12	12 - 24
23 Schweißpositionen	H-L045 (steigend)	PA, PC, PE, PF, PH, H-L045
24 Schweißnaht Einzelheiten	ss nb (einseit. o.B.)	ss nb, ss mb, bs

25 Hinweise Erfüllt die Richtlinie 97/23/EG.

26	Art der Prüfung	ausgeführt und bestanden	nicht verlangt
30	Sichtprüfung	Ja	-
31	Durchstrahlungsprüf.	Ja	-
32	Magnetp./Farbeindring.	-	x
33	Kerbzugprüfung	-	x
34	Bruchprüfung	-	x
35	Biegeprüfung	-	x
36	Makroskop. Untersuchung *)	-	x

Name und Unterschrift: **Steffen Kuntzsch**  
 TÜV SÜD Industrie Service GmbH  
 Zertifizierstelle für Personal  
 Datum des Schweißens: 28.11.2013  
 Ort / Datum: Königsbrück 10.12.2013  
 Gültigkeit der Prüfung: 27.11.2015

VERLÄNGERUNG DER PRÜFUNG DURCH  
BESTÄTIGUNG DES(R) ARBEITGEBER(S) ODER  
PRÜFAUFSICHT



37 \*)falls notwendig, Angaben auf Zusatzblatt

38 VERLÄNGERUNG DER PRÜFUNG DURCH PRÜFSTELLE

39	Datum	Unterschrift	Dienststellung oder Titel

Datum	Unterschrift	Dienststellung oder Titel

40 TÜV SÜD Industrie Service GmbH, Drescherhäuser 5d, Dresden, Telefon +49 351 4202 -235, Fax -230  
 inge-lore.reschies@tuev-sued.de - Echtheit des Zertifikats mit QR-Code verifizierbar © WordWeld 2.5.1



de (D)	en (GB)	fr (F)	it (I)
1 SCHWEISSER-PRÜFUNGSBESCHEINIGUNG ZERTIFIKAT	1 WELDER APPROVAL TEST CERTIFICATE	1 CERTIFICAT DE QUALIFICATION DE SOUDEUR	1 CERTIFICAZIONE DELLA QUALIFICA DI SALDATURA
2 BEZEICHNUNG	2 DESIGNATION	2 DESIGNATION	2 DENOMINAZIONE
3 Seite von	3 Page of	3 Page de	3 Pagina di
4 Hersteller - Schweißanweisung Prüfstelle	4 Manufacturer's Welding Procedure Specification Inspecting Authority	4 Mode opératoire de soudage du constructeur	4 Istruzioni di saldatura del costruttore
5 Beleg-Nr. (falls verfügbar): / Prüf-Nr.:	5 Reference N°:	5 N° de référence: / N° de référence:	5 Nr. del giustificativo (se esistente) (nr. di collaudo)
6 Name des Schweißers:	6 Welder's Name:	6 Nom du soudeur:	6 Nome del saldatore
7 Legitimation:	7 Identification:	7 Identification:	7 Legittimazione nr.
8 Art der Legitimation: Fotografie	8 Method of identification: Photograph	8 Méthode d'identification: Photographie	8 Tipo di legittimazione: Fotografia
9 Geburtsdatum und -ort: / (falls nötig)	9 Date and place of birth: / (if required)	9 Date et lieu de naissance: / (si demandée)	9 Data e luogo di nascita (se necessario)
10 Beschäftigt bei:	10 Employer:	10 Employeur:	10 Dipendente presso:
11 Vorschrift / Prüfnorm:	11 Code / Testing Standard:	11 Code / Norme de essai:	11 Prescrizione / Norma di collaudo
12 Fachprüfung: Bestanden / nicht geprüft (Unzulaffendes streichen)	12 Job knowledge: Acceptable / not loaded (delete as necessary)	12 Vérification des connaissances: Acceptable / non vérifiée (rayer la mention inutile)	12 Esame tecnico: Superato / non sottoposto ad esame (Cancellare la voce che non interessa)
13 Prüfdaten - Angaben Gefügebereich	13 Weld test details: Range of approval	13 Éléments de l'essai: Domaine de validité	13 Dati - Indicazioni del collaudo: Campo di validità
14 Schweißverfahren	14 Welding process	14 Procédé de soudage	14 Procedimento di saldatura
15 Blech oder Rohr	15 Plate or pipe	15 Tôle ou tube	15 Lamiera o tubo
16 Nahtart	16 Joint type	16 Type de joint	16 Tipo di smusso
17 Werkstoffgruppe(n)	17 Parent metal group	17 Groupe du métal de base	17 Gruppo / gruppi di materiale
18 Zusatzstoff / Bezeichnung	18 Filler metal type / designation	18 Type du métal d'apport	18 Tipo del materiale di apporto / denominazione
19 Schutzgas / Pulver	19 Gas / flux	19 Gaz de protection	19 Gas inerte / polvere
20 Hilfsstoffe	20 Auxiliaries	20 Auxiliaires de soudage	20 Materiali ausiliari
21 Prüfstückdicke [mm]	21 Material thickness [mm]	21 Épaisseur du matériau [mm]	21 Spessore del pezzo in prova [in mm]
22 Rohraußendurchmesser [mm]	22 Pipe outside diameter [mm]	22 Diamètre extérieur du tube [mm]	22 Diametro esterno del tubo [mm]
23 Schweißpositionen	23 Welding positions	23 Positions de soudage	23 Posizioni di saldatura
24 Ausfügen / Badsicherung	24 Gouging / Backing	24 Gougeage / Reprise envers	24 Molatura delle radici / Protezioni del bagno
25 Zusätzliche Hinweise siehe beigefügtes Blatt und/oder Schweißanweisung Nr.:	25 Additional information is available on attached sheet and / or welding procedure specification N°:	25 Des informations supplémentaires sont données sur la feuille jointe et/ou sur la spécification de soudage N°:	25 Ulteriori indicazioni - vedi foglio allegato e/o istruzioni di saldatura nr.
26 Ausgeführt und, Name und Unterschrift	26 Performed and, Name and Signature	26 réalisée et, Nom et signature	26 Compilato e, nome e firma
27 Art der Prüfung	27 Type of test	27 Type d'essai	27 Tipo di collaudo
28 bestanden, nicht verlangt	28 acceptable - not required	28 acceptable / non requis	28 Superato, non richiesto
29 Prüfstelle	29 Inspecting Authority	29 Organisme de contrôle	29 Centro di collaudo
30 Sichtprüfung	30 Visual	30 Visuel	30 Esame visivo
31 Durchstrahlungsprg. / Tag der Ausgabe:	31 Radiography / Date of issue:	31 Radiographie / Date d'émission:	31 Esame radiografico / giorno del rilascio
32 Magnetpulver- / Farblösungsprüfung Ort:	32 Magnetic particle / Penetrant Location:	32 Magnétoscopie / Ressuage Lieu:	32 Esame magnetoscopico / liquido penetrante Luogo:
33 Makroschliff	33 Macro	33 Macroscopie	33 Prova per esame macrostruttura
34 Gültigkeit der Prüfung:	34 Validity of approval until:	34 Certifié valable jusqu'à:	34 Validità dell' esame
35 Bruchprüfung	35 Fracture	35 Texture	35 Prova di rottura
36 Biegeprüfung	35 Bend	35 Pliage	35 Prova a flessione
37 VERLÄNGERUNG DER PRÜFUNG DURCH BESTÄTIGUNG DES/ER ARBEITGEBER(S) ODER PRÜFAUFSICHT	37 PROLONGATION FOR APPROVAL BY EMPLOYER / SUPERVISOR	37 PROLONGATION DE VALIDITÉ PAR L'EMPLOYEUR	37 ESTENSIONE DELLA QUALIFICA TRAMITE CONFERMA DEL DATORE / DEI DATORI DI LAVORO O DELLA SORVEGLIANZA DELL' ESAME
38 Zusatzprüfungen	38 Additional Tests	38 Autres	38 Prove supplementari
39 Datum, Unterschrift, Dienststellung oder Titel	39 Date, Signature Position or Title	39 Date, Signature Position or titre	39 Data, firma Funzione o titolo
38 VERLÄNGERUNG DER PRÜFUNG DURCH PRÜFER / PRÜFSTELLE	38 PROLONGATION FOR APPROVAL BY INSPECTING AUTHORITY	38 PROLONGATION DE VALIDITÉ PAR L'ORGANISME DE CONTRÔLE	38 ESTENSIONE DELLA QUALIFICA TRAMITE IL COLLAUDATORE / CENTRO DI COLLAUDO
39 Datum, Unterschrift, Dienststellung oder Titel	39 Date, Signature Position or Title	39 Date, Signature Position ou titre	39 Data, firma Funzione o titolo

es (E)	po (P)	un (H)	ts (CZ)
1 CERTIFICADO DE EXAMEN DE SOLDADOR	1 CERTIFICADO DE QUALIÇÃO DE SOLDADOR	1 HEGESZTŐVIZSGA BIZONYÍTVÁNY	1 OSVÉDÉSENI O SVAREČSKÉ ZKOUŠCE
2 No. de referencia: DESIGNACIÓN	2 Referencia No.: DESIGNAÇÃO	2 JEJÓLES	2 OZANČENÍ
3 Página de	3 Página de	3 Órdalak száma	3 Strana z
4 Instrucción de soldadura del fabricante	4 Especificação do Procedimento de Soldadura do Construtor	4 A gyártó hegesztési utasítása	4 Podmínky výroby pro svařování Příkladů nebo v
5 No. de referencia:	5 Referencia No.:	5 Vizsgáztató	5 Příkladů nebo v
6 Apellido y nombre del soldador:	6 Nome do soldador:	5 Brochnyílát sz. /ha ven-/ Vizsgázám	5 Císelné označení podmínek (je-li k dispozici) / zkouška č.:
7 Identificación:	7 Identificação:	6 Hegesztő neve:	6 Úmístě svařecí
8 Método de identificación:	8 Metodo de identificação:	6 Azonosítójel:	7 Průkaz:
9 Fecha de nacimiento y lugar:	9 Data e local de nascimento:	8 Azonosítási módja:	8 Druh průkazu:
10 Empleado de:	10 Empresa:	8 Szűréses idő és hely: /ha szükséges/	9 Datum a místo narození.
11 Código / Norma de comprobación:	11 Código / Norma de ensaios:	9 Munkaadó	9 Zaměstnan u:
12 Datos del examen	12 Conhecimentos do trabalho	10 Szakmai ismeret.	10 Předpis/norma:
13 Alcance de validez:	13 Detalhes do exame	11 Vizsgáztelési előírás, szabvány	11 Osbornou zkoušku: složil/nesložil (nehodil se /škrtně)
14 Proceso de soldadura	14 Campo de validade	12 Sikeres vizsgát tett / nem vizsgát (a nem megfelelő rész törölendő)	12 Zkušební data-odaje
15 Chapa o tubo	15 Chapa ou tubo	13 Vizsgaadatok	13 Oblast platnosti
16 Forma de soldadura	16 Tipo de junta	14 Érvényességi tartomány	14 Svařovací postup
17 Grupo(s) de material(es) base(s)	17 Grupo do(s) material(is) base(s)	14 Hegesztési eljárás	15 Ploch nebo rovna
18 Material de aportación / designación	18 Tipo de material de adição / designação	15 Lemez vagy cső	16 Druh svaru
19 Gas de protección	19 Gas	16 Varratírtás	17 Materálová skupina
20 Material auxiliar	20 Auxiliares	17 Anyagcsoport	18 Příkladné materiály/označení
21 Espesor del material [mm]	21 Espessura do material base [mm]	18 Hozaganyag / Jelölés	19 Ochranný plyn/tavidó
22 Diametro exterior do tubo [mm]	22 Diâmetro exterior do tubo [mm]	19 Védőgáz / por	20 Pomocná látka
23 Posición de soldadura	23 Posições de soldadura	20 Segédanyagok	21 Tloušťka vzorku /mm/
24 Descarnar / Respaldo	24 Limpeza da raiz / Cobrejunta	21 Vizsgádtárgy vastagsága (mm)	22 Vnější průměr roviny /mm/
25 Información adicional:	25 Informação adicional:	22 Cső külső átmérője (mm)	23 Svařovací pozice
26 Realizado y, apellido, nombre y firma	26 Realizado e, Nome e assinatura:	23 Hegesztési pozíciók	24 Odstránění kořene/ochrana tážné
27 Tipo de prueba	27 Tipo de teste	24 Gyökértáji kimunkálás / varratmeglazítás	25 Ostatní podrobnosti viz příložený list a/ nebo svařecský průkaz č.:
28 aprobado, no requerido	28 aceitado, não requerido	25 Kiegészítő utasításokat lásd a mellékelt lapon és/vagy a ..... sz. hegesztési utasításban.	26 Vytínáno a.
29 Organismo de control	29 Entidade inspectora	26 Kivitelezett és. Név és aláírás	27 Druh zkoušky
30 Control visual	30 Visual	27 Vizsgálat módja	28 Spinil, není požadováno
31 Radiografía / Fecha de edición:	31 Radiografía / Data de emissão:	28 megfelelő, nem szükséges	28 Gódkoušeno v
32 Partículas magnet. / Líquidos penetrantes	32 Magnétoscopia / Líquidos penetrantes	29 Vizsgáztató	29
33 Lugares	33 Lugares	29 Szemrevételezés	29 Vizuální zkouška
34 Macrografía	34 Macrografía	30 Radiográfiai vizsgálat / a kibocsátás napja:	30 Zkouška prozáření/men vyhotovení
35 Valides del examen	35 Aprovação válida até:	31 Radiográfiai vizsgálat / a kibocsátás napja:	31 Zkouška magnetickými částicemi/ barevná indikace Misto:
36 Ensayo de rotura	36 Dobrotem	32 Mágnespóros / behatóidővizsgálás	32 Makro vybrus
37 PRORROGA DE VALIDEZ POR CONFIRMACIÓN DE LA EMPRESA O DEL PERSONAL SUPERVISOR	37 REVALIDAÇÃO PELA EMPRESA / SUPERVISOR	33 repedésvizsgálat Hely:	33 Platnost zkoušky
38 Ensayo adicionales	38 Outros testes	34 Makroszelekt	34 Lomová zkouška
39 Fecha, Firma	39 Data, Assinatura	35 A vizga érvényessége:	35 Zkouška slyhem
38 PRORROGA DE VALIDEZ POR ORGANISMO DE CONTROL	38 REVALIDAÇÃO PELA ENTIDADE INSPECTORA	36 Törépróba	36 PRODLUŽENÍ ZKOUŠKY
39 Fecha, Firma	39 Data, Assinatura	37 Hagítópróba	36 POTVRZENÍ ZAMĚSTNAVATELE, NEBO ZKUSEBNÍHO DOHLEDU
39 Posición o título	39 Posição ou título	38 A VIZSGA MEGHOSSZABBÍTÁSA A MUNKAADÓ VAGY FELÜGYELETI SZEMÉLY IGAZOLÁSAVAL	37 Příkladné zkoušky
		39 Kiegészítő vizsgálatok	37 Datum, podpis
		39 Dátum, Aláírás	38 Stážovní postavení, nebo titul
		39 Munkaadó vagy a címe	38 PRODLUŽENÍ ZKOUŠKY ZKUSEBNÍ ORGANIZACI/MISTO PŘEZKOUŠENÍ
		39 A VIZSGA MEGHOSSZABBÍTÁSA A VIZSGÁZTATÓ/A VIZSGÁZTATO HELY ÁLTAL	39 Datum, podpis
		39 Dátum, Aláírás	39 Stážovní postavení nebo titul
		39 Vizsgáztató, vagy a címe	



# Declaration of decontamination

Because of the legal regulations and for the safety of our employees it is mandatory for you to fill out this declaration of decontamination and sign it before your order can be handled.

**Please attach this document well readable and protected from wetness on the outside of the packaging and place a copy with the shipment papers.**

Device/component \_\_\_\_\_

Serial no. \_\_\_\_\_

Point of use/environment \_\_\_\_\_

**Reason for sending in:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Was the device in operation?**

- No – Device still in the packaging.  
 No – Unpacked, but not in operation.  
 Yes – operated with:

**Contamination:**

Could the component be contaminated?  No  Yes, contaminated with: \_\_\_\_\_



explosive



flammable



oxidizing



corrosive



toxic



health hazard



environm. hazard



other



harmless

The device/component was purged with: \_\_\_\_\_

**Sender:**

Company \_\_\_\_\_ Contact person \_\_\_\_\_

Street \_\_\_\_\_ Phone \_\_\_\_\_

Zip code, city \_\_\_\_\_ E-Mail \_\_\_\_\_

I confirm, that the device/component mentioned above is free of hazardous or potential hazardous substances. This declaration of decontamination has been filled in to the best of our knowledge und was signed by an authorized person.

**Legally binding declaration:**

I hereby confirm, that die statements in this form are correct and complete. The shipment of the (decontaminated) devices and components follows the legal regulations.

Name (in block letters) \_\_\_\_\_ Company stamp \_\_\_\_\_

Position \_\_\_\_\_

Place, Date \_\_\_\_\_

Legally binding signature \_\_\_\_\_

## 14.10 Component documentation



### NOTICE!

The data sheets for the components are in pdf-format on the attached CD. They are not printed out because of their high page count and environmental concerns.



→ Please refer to the CD, if you need a certain data sheet or manual.



**CS-UK-LTD****SERVICE REPORT**

Date: 15/03/2016	Purchase Order: N/A	Engineer: S.Johnstone
Client: Nines PV	Address: University of Sheffield, NanoScience & Technology Building, Broad Lane, Sheffield, S3 7HQ	
Contact Person: Laurent Clochard		
Tel: N/A		
Reason For Visit: To Commission 1 off CP500SF & 1 off CS200BS		
Description of Work:  Commissioning of CS200BS, Serial No. CS150042. System installed in Lab area for Photovoltaics PECVD. Remove inlet/outlet caps & complete visual inspection of all components. Power up unit spur & switch on internal fuses. Open external N2 supply & regulate pressure to 6 bar, set internal regulator to 0.3bar. Check & tighten all internal connections & fixings. Install 250mm St/St flexible on outlet of system on customer's behalf. Install column, CC1891, & connect inlet & outlet flexible & Kf40 clamps & centring rings. Full function test of bypass actuator & gas detection sample unit. Function test of detection N2 purge. Install internal gas detection for monitoring of outlet concentrations, TX-1461-KFP, serial no. 903404 & GS-1461DP(F2) cell, serial no. 889144. Full test of sensor using 2ppm Cl2 gas. Pressure drop test across system @ 0.2bar for 1 hour, all ok. System ready for process.  Commissioning of CP500SF, with in-line filter, serial no. 150004. CP500 installed in container with internal heating supplied. CP for emergency abatement on gas Cabinet. Removed both upper & column lids to check granulate levels after shipping, all ok. Reinstalled lids. Inspection of Pre-filter installation, all ok. Fan switched on & magnehelic readings recorded, CP Granulate bed 0 Pascal's & CP filter 0 Pascal's. System ready for process.		
Materials:	Additional Comments:	
	Temporary N2 supply installed on CS-200-BS system. Customer advised that permanent 6 Bar supply was to be installed, which was due to be done after commissioning visit.	
Print: Scott Johnstone	System training on both systems carried out with names of attendees below,	
Signature:	Ed Duffy, Laurent Clochard & John Clarke	
Date: 15/03/2016		



Date: 15-03-2016 Service no : \_\_\_\_\_ Engineer: Scott Johnstone

Client: NINES PV Address: Nines Photovoltaics, Synergy Centre, IT Tallaght, Dublin, Ireland

Location: Lab Area Responsible: Laurent Clochard

Order/Ref no. Client: Commissioning Visit Tel: 00353 (0) 76 6152321

Start-up:  Commissioned :  Repair:  Extra Work:  Other:

**Description:**

Commissioned & calibrated internal gas detection unit on CS-200BS system monitoring outlet concentrations.

1 x Fluorine: TX-1461-KFP sensor serial no. 903404 & GS-1461-DP cell, serial no. 889144

Calibrated using 2ppm Cl2.

Calibration successful and operation of Sensor correct

Quick connect & sample lines clean.

Next service due March 2017.

Materials	Quantity	Labour & Travel Cost	Quantity
Electrolyte	_____	Labour hours	<u>1 hr</u>
Membranes	_____	Travel hours	<u>N/A</u>
"O" ring	_____	Travel km/Miles	_____
Gen tubes	_____	Living cost € / £	_____
Gen liquid	_____	Backup SIMS / Pact	Backup performed: <input type="checkbox"/>
Test canisters	_____		
Pyrolyser	_____	Date: <u>15 / 03 / 2016</u>	Start: _____ hour
Cal tubes	_____		End : _____ hour
<b>Other Consumables:</b>		Date: <u> / /</u>	Start: _____ hour
<u>Calibration Gas Cl2 2ppm</u>			End : _____ hour
_____		Date: <u> / /</u>	Start: _____ hour
_____			End : _____ hour
_____		Date: <u> / /</u>	Start: _____ hour
_____			End : _____ hour

Client Signature: \_\_\_\_\_ Date: \_\_\_\_\_