



Category	Value	Requirements	Fullfill?
Space heating	Annual heating demand: 25 kWh/m²/a	25 kWh/m²/a	yes
Space heating	Overall specific space heating demand: 15 kWh/m²/a	-	-
Space heating	Frequency of overheating > 25 °C: 0.5	-	-
Primary Energy	Space heating and cooling: 99 kWh/m²/a	133 kWh/m²/a	yes
Primary Energy	Space heating and auxiliary electricity: 47 kWh/m²/a	-	-
Primary Energy	Specific primary energy reduction through solar electricity: 5 kWh/m²/a	-	-
Airtightness	Permeation test result (q): 1.0	1.5	yes

