

EXISTING EXTERNAL CONCRETE UP STAND WALL WITH MOSAIC TILE FINISH UVALUE = 3.33 W/(M2)

EXISTING ROTARY AIR VENT

EXISTING SINGLE GLAZED NON THERMALLY BROKEN ALUMINIUM WINDOW UVALUE = 5.69 W/(M2)

BASLINE WINDOW HEAD

EXISTING STAIRWELL

EXISTING STAIR CORE WITH SINGLE ESCAPE ROUTE

STORE

TOILET

EXISTING LIFT SHAFT

OPEN PLAN OFFICE

EXISTING EXTERNAL CONCRETE UP STAND WALL WITH MOSAIC TILE FINISH UVALUE = 3.33 W/(M2)

EXISTING SINGLE GLAZED NON THERMALLY BROKEN ALUMINIUM WINDOW UVALUE = 5.69 W/(M2)

BASLINE FLOOR PLAN

PHOTO VALIDATION OF SHADING - 12th Dec

VALIDATION MODEL - 12th Dec

EXISTING WINDOW SPANDREL PANEL UVALUE = 2.26 W/(M2)

BASLINE SPANDREL PANEL

SOLAR RADIATION

Solar radiation + Ambient temperature

21st July - 9.00am

21st July - 3.00pm

EXISTING EXTERNAL CONCRETE UP STAND WALL WITH MOSAIC TILE FINISH UVALUE = 3.33 W/(M2)

BASLINE WINDOW CILL

Façade Baseline					
Heat Distribution During Occupancy Hours (3032 Hrs)					
Zone	Hours Above 25°C	Hours Above 28°C	Zone	Hours Above 25°C	Hours Above 28°C
South Office	21	0	West Office	34	0
East Office	29	0	Target Hours	5% = 151.60 Hours	1% = 30.32 Hours

BASLINE HEAT DISTRIBUTION

21st Dec - 9.00am

21st Dec - 3.00pm

LIBERTY HALL - BASELINE

PRIMARY ENERGY SAVINGS

TOTAL BASELINE ENERGY CONSUMPTION = 124,276 kWh

Electricity 68,260 kWh x 0.19 Cent €12,969

Oil 56,016 kWh x 0.06 Cent €3,360

Energy Cost Per Floor = €16,329

Total Energy Cost for Building (17 Floors) = €16,329 x 17 = €277,593

TOTAL OPTIMISED SPECIFICATION ENERGY CONSUMPTION = 18,007 kWh

Electricity 7,598 kWh x 0.19 Cent €1,443

Oil 50,924 kWh x 0.06 Cent €3,055

Energy Cost Per Floor = €4,527

Total Energy Cost for Building (17 Floors) = €4,527 x 17 = €76,959

REDUCTION IN ENERGY CONSUMPTION FROM BASELINE = 86%

REDUCTION IN ENERGY COST FROM BASELINE = 80%

	Delivered Energy (kWh)			Primary Energy (kWh)		
	Oil	Electrical	Total	Oil	Electrical	Total
Baseline	50,924	28,802	79,726	56,016	68,260	124,276
Option A	12,788	27,774	40,562	14,066	65,824	79,890
Option B	12,616	27,921	40,537	13,877	66,172	80,049
Option C	14,360	27,950	42,310	15,796	66,241	82,037
Optimised	0	7,598	7,598	0	18,007	18,007

SUN SHADING STUDY

TOTAL BASELINE ENERGY CONSUMPTION = 79,726 kWh

Electricity 28,802 kWh x 0.19 Cent €5,472

Oil 50,924 kWh x 0.06 Cent €3,055

Energy Cost Per Floor = €8,527

Total Energy Cost for Building (17 Floors) = €8,527 x 17 = €144,959

TOTAL OPTIMISED SPECIFICATION ENERGY CONSUMPTION = 7,598 kWh

Electricity 7,598 kWh x 0.19 Cent €1,443

Oil 50,924 kWh x 0.06 Cent €3,055

Energy Cost Per Floor = €4,527

Total Energy Cost for Building (17 Floors) = €4,527 x 17 = €76,959

REDUCTION IN ENERGY CONSUMPTION FROM BASELINE = 91%

REDUCTION IN ENERGY COST FROM BASELINE = 84%

ENERGY BREAKDOWN

ENERGY BREAKDOWN

LOCATION OF NEW PV SOLAR ELECTRICAL PANELS

PROPOSED OPTIWIN 120+ PASSIVE WINDOWS UVALUE = 0.85 W/(M2)

UPGRADED EXTERNAL UP STAND WALLS UVALUE = 0.14 W/(M2)

OPTIONAL PV PANELS FITTED VERTICALLY TO UP STAND WALLS

OPTIMISED ELEVATION

WINDOW HEAD DETAIL

Existing concrete structure

Compaction support for new passive windows

Expanding foam sealant tape

Monar Jointery Eco-Clad 120+ Passive windows with a U-Value of 0.86 W/(M2)

Saint Gobain Plinthem stone glazed unit with a low E value of 0.25 and a high light transmittance value of 0.70 with low iron clear glass

12.5mm Ogypson plasterboard

12.5mm Ogypson plasterboard

Compaction support for new passive windows

Monar Jointery Eco-Clad 120+ Passive windows

Form slip at edge of covering

12.5mm Ogypson plasterboard

12.5mm Ogypson plasterboard

Existing concrete structure used as air tightness layer

WINDOW CILL DETAIL

SOUTH OFFICE - SUMMER DESIGN WEEK

Temperature and Heat Gains - Typical Floor, South Office

17 Feb - 18 Feb (20 consecutive occupied periods)

OPTIMISED FLOOR LAYOUT

STAFF TOILETS

STAIR CORE

OPEN PLAN OFFICE

WINDOW CILL DETAIL

PHENOLIC FOAM INSULATION 0.025 W/M2

COMPACT FOAM INSULATION 0.04 W/M2

INTERNAL SOLAR CONTROL BLINDS

OPTIMISED WINDOW HEAD DETAIL

SOUTH OFFICE - WINTER DESIGN WEEK

Temperature and Heat Gains - Typical Floor, South Office

10 Feb - 18 Feb (20 consecutive occupied periods)

MECHANICAL DUCTWORK LAYOUT

AIR TIGHTNESS MEMBRANE SEALED TO CONCRETE CEILING WITH AIR TIGHTNESS TAPE

AIR TIGHTNESS MEMBRANE SEALED TO PASSIVE WINDOW WITH AIR TIGHTNESS TAPE

AIR TIGHTNESS MEMBRANE SEALED TO CONCRETE CEILING WITH AIR TIGHTNESS TAPE

AIR TIGHTNESS MEMBRANE SEALED TO PASSIVE WINDOW WITH AIR TIGHTNESS TAPE

AIR TIGHTNESS MEMBRANE SEALED TO CONCRETE CEILING WITH AIR TIGHTNESS TAPE

AIR TIGHTNESS MEMBRANE SEALED TO PASSIVE WINDOW WITH AIR TIGHTNESS TAPE

EXTRACT FROM ALL WET ROOMS AND FROM OFFICE AREA

TGD PART M - SANITARY COMPLIANCE

Male WC

Female WC

Disabled WC

Office Area

OPTIMISED WINDOW CILL DETAIL

PROPOSED OPTIWIN 120+ PASSIVE WINDOWS UVALUE = 0.85 W/(M2)

UPGRADED EXTERNAL UP STAND WALLS UVALUE = 0.14 W/(M2)

OPTIWIN 120+ PASSIVE WINDOW DETAIL

TGD PART B - FIRE REGULATION COMPLIANCE

120+ Minute Fire Compartment Wall

Travel Distance = 10.47m

Travel Distance = 6.50m

LAYOUT OF PV RENEWABLE ENERGY PANELS

LOCATION OF NEW PV SOLAR ELECTRICAL PANELS

PROPOSED OPTIWIN 120+ PASSIVE WINDOWS UVALUE = 0.85 W/(M2)

OPTIONAL PV PANELS FITTED VERTICALLY TO UP STAND WALLS

LIBERTY HALL - OPTIMAL SPECIFICATION

THERMAL BRIDGE ANALYSIS

Temperature 17°C

Detail 2D

U-value 101: 0.234 W/m²K

Length Outside: 282 mm

Length Inside: 472 mm

Delta T Element 1: 20 K

Element 1

U-value 102: 0.932 W/m²K

Length Outside: 637 mm

Length Inside: 472 mm

Delta T Element 2: 20 K

Element 2

U-value 103: 0.313 W/m²K

Length Outside: 1438 mm

Length Inside: 28 mm

Delta T Element 2: 20 K

Element 2

ψ_i (Part L): 0.028 W/m²K

ψ_e (for PHPP): 0.016 W/m²K

OPTIMISED WINDOW CILL LINEAR THERMAL BRIDGE

UVALUE CALCULATION WITH HYGROTHERMAL ANALYSIS

Surface temperature to avoid critical surface humidity Calculation according BS EN ISO 13788

Location: Dublin, Humidity class according BS EN ISO 13788 annex C: Offices, shops

Month	1	2	3	4	5	6	7	8	9	10	11	12
January	0.2	0.2001	0.2002	0.2003	0.2004	0.2005	0.2006	0.2007	0.2008	0.2009	0.2010	0.2011
February	0.2	0.2001	0.2002	0.2003	0.2004	0.2005	0.2006	0.2007	0.2008	0.2009	0.2010	0.2011
March	0.2	0.2001	0.2002	0.2003	0.2004	0.2005	0.2006	0.2007	0.2008	0.2009	0.2010	0.2011
April	0.2	0.2001	0.2002	0.2003	0.2004	0.2005	0.2006	0.2007	0.2008	0.2009	0.2010	0.2011
May	0.2	0.2001	0.2002	0.2003	0.2004	0.2005	0.2006	0.2007	0.2008	0.2009	0.2010	0.2011
June	0.2	0.2001	0.2002	0.2003	0.2004	0.2005	0.2006	0.2007	0.2008	0.2009	0.2010	0.2011
July	0.2	0.2001	0.2002	0.2003	0.2004	0.2005	0.2006	0.2007	0.2008	0.2009	0.2010	0.2011
August	0.2	0.2001	0.2002	0.2003	0.2004	0.2005	0.2006	0.2007	0.2008	0.2009	0.2010	0.2011
September	0.2	0.2001	0.2002	0.2003	0.2004	0.2005	0.2006	0.2007	0.2008	0.2009	0.2010	0.2011
October	0.2	0.2001	0.2002	0.2003	0.2004	0.2005	0.2006	0.2007	0.2008	0.2009	0.2010	0.2011
November	0.2	0.2001	0.2002	0.2003	0.2004	0.2005	0.2006	0.2007	0.2008	0.2009	0.2010	0.2011
December	0.2	0.2001	0.2002	0.2003	0.2004	0.2005	0.2006	0.2007	0.2008	0.2009	0.2010	0.2011

ψ_i (Part L): 0.028 W/m²K

ψ_e (for PHPP): 0.016 W/m²K

BASELINE SPANDREL PANEL UVALUE AND HYGROTHERMAL ANALYSIS

UVALUE CALCULATION WITH HYGROTHERMAL ANALYSIS

Surface temperature to avoid critical surface humidity Calculation according BS EN ISO 13788

Location: Dublin, Humidity class according BS EN ISO 13788 annex C: Offices, shops

Month	1	2	3	4	5	6	7	8	9	10	11	12
January	0.2	0.2001	0.2002	0.2003	0.2004	0.2005	0.2006	0.2007	0.2008	0.2009	0.2010	0.2011
February	0.2	0.2001	0.2002	0.2003	0.2004	0.2005	0.2006	0.2007	0.2008	0.2009	0.2010	0.2011
March	0.2	0.2001	0.2002	0.2003	0.2004	0.2005	0.2006	0.2007	0.2008	0.2009	0.2010	0.2011
April	0.2	0.2001	0.2002	0.2003	0.2004	0.2005	0.2006	0.2007	0.2008	0.2009	0.2010	0.2011
May	0.2	0.2001	0.2002	0.2003	0.2004	0.2005	0.2006	0.2007	0.2008	0.2009	0.2010	0.2011
June	0.2	0.2001	0.2002	0.2003	0.2004	0.2005	0.2006	0.2007	0.2008	0.2009	0.2010	0.2011
July	0.2	0.2001	0.2002	0.2003	0.2004	0.2005	0.2006	0.2007	0.2008	0.2009	0.2010	0.2011
August	0.2	0.2001	0.2002	0.2003	0.2004	0.2005	0.2006	0.2007	0.2008	0.2009	0.2010	0.2011
September	0.2	0.2001	0.2002	0.2003	0.2004	0.2005	0.2006	0.2007	0.2008	0.2009	0.2010	0.2011
October	0.2	0.2001	0.2002	0.2003	0.2004	0.2005	0.2006	0.2007	0.2008	0.2009	0.2010	0.2011
November	0.2	0.2001	0.2002	0.2003	0.2004	0.2005	0.2006	0.2007	0.2008	0.2009	0.2010	0.2011
December	0.2	0.2001	0.2002	0.2003	0.2004	0.2005	0.2006	0.2007	0.2008	0.2009	0.2010	0.2011

ψ_i (Part L): 0.028 W/m²K

ψ_e (for PHPP): 0.016 W/m²K

OPTIMAL EXTERNAL WALL UVALUE AND HYGROTHERMAL ANALYSIS