



DANIEL COYLE BA(Hons) BArch MRIAI ARCHITECT DUBLIN SCHOOL OF ARCHITECTURE, DUBLIN INSTITUTE OF TECHNOLOGY, BOLTON STREET, DUBLIN 1 info@danielcoylearchitects.ie

nZEB OFFICE RETROFIT PROJECT MSc ENERGY RETROFIT TECHNOLOGY DT774b

nZEB OFFICE RETROFIT - AER LINGUS H.O.B.







Existing Building BER nZEB Retrofit BER

EXISTING BUILDING ENGERY ANALYSIS

lation Results - Energy Use Breakdowr

Exis

Arising from the Recast European Performance

of Buildings Directive 2010/30/EU, from January 1st 2021 every new building in Ireland will have

to be designed to near zero energy building

standards (nZEB) - meaning buildings with an

ultra low energy demand for heating, cooling,

ventilation, light and power, and with this

residual energy demand being met mainly by on

The project investigates a range of low-energy

retrofit measures for the upgrade and

refurbishment of an existing multi-storey office building to the nZEB standard. The subject

building is the old Aer Lingus Head Office

Building, located at Dublin Airport, Swords, Co

The study was carried out using a range of

energy performance analysis tools including

Design Builder Dynamic Simulation Software.

The study was both an investigation into low-

study of the Dynamic Simulation tool itself.

energy building retrofit design, as well as a

The focus of the project was to explore Passive

Architectural Solutions to deliver optimal "load

reductions" - By engineering the fundamental

form and envelope of the building correctly to

exploit passive heating, cooling, ventilation and

lighting resources, the greatest reductions in

The total Annual Energy Demand for the

retrofitted office building has been reduced by

over 70%, Annual Space Heating Demand


reduced by nearly 90%, and internal comfort conditions for the building maintained without

overall energy use can be achieved.

the need for Air Conditioning.

Dublin

site or nearby Renewable Energy Sources.



(1) Large Ventilation Heat Losses (Nat Vent & Mech /entilation without heat recovery). (2) Infiltration Heat Losses (the building envelope is very leaky).

(4) Fabric Heat Losses (very poor fabric U-Values + lots of Linear Thermal Bridging).

Aux Energy

Space Heating

45 kWh/m2

8.3

5.2


Optimal


Electrical

Lighting

(3) Glazing Heat losses (Glazing and Frame

losses).









NAT VENT (VARIABLE) FABRIC LOSSES (VARIABLE) FABRIC INFILTRATION 14W/m2 (VARIABLE)

Dynamic Simulation Schematic - Modelling a complex reality



Dynamic Simulation Inputs & Output results - Ventilation, Annual Energy Use, Loads, & Heat Gains

nZEB RETROFIT STRATEGY



1. FABRIC & GLAZING UPGRADES (PASSIVHAUS ENERPHIT STANDARD):

Fabric Element		Existing	Retrofit
External (Glazed) Wall U-Value	Э	0.83 (W/m2K)	0.10 (W/m2K)
Gable Walls U-Value	Cuality Approved Energy Retrofit with Passive House Components Passive House Institute	1.72 (W/m2K)	0.12 (W/m2K)
Flat Roof U-Value		1.00 (W/m2K)	0.11 (W/m2K)
Ground Floor U-Value		0.77 (W/m2K)	0.12 (W/m2K)
Window U-Value (Ug)		2.40 (W/m2K)	0.75 (W/m2K)
Thermal Bridging Elements		0.98 - 1.81 W/mK	max + 0.01 W/mK
Airtightness (Infiltration Rate)		15 ach-1 @ 50 Pascals	1.0 ach-1 @ 50 Pascals


2. OPTIMISED DAYLIGHTING:

Hrs Hrs +25°C +28°C

47.3


53.6

26.5



Daylight Strategy: (1) Glare zone (desk work areas set-back from perimeter), (2) Office working areas with good daylight distribution (200-500 lux), (3) Circulation and ancillary spaces to central zone with lower daylighting levels (>200 lux).

3. LOW ENGERY LIGHTING STRATEGY (1.6 W/m2 100 lux):



Existing Building Simulation Analysis - Overheating Summer Design Week Annual Energy Use

