

PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT **nZEB OFFICE RETROFIT PROJECT**

b m n а S n Retrofit A R C H 2 2 8 1 : Technology Project

nZEB OFFICE RETROFIT - LIBERTY TOWER


Arising from the Recast European Performance of Buildings Directive 2010/30/EU, from January 1st 2021 every new building in Ireland will have to be designed to near zero energy building standards (nZEB).

This project investigates a range of low energy retrofit measures for the upgrade and refurbishment of an existing multi-storey office building to nZEB standard, located in Dublin City centre.


The study was carried out using a range of energy analysis performance tools including Design Builder Dynamic Simulation software, Therm software for linear thermal bridge analysis and BuildDesk U for U-value and condensation risk assessment. The bulk of analysis was performed using Design Builder in which a typical floor plan was modelled for both the baseline assessment and the proposed retrofit solution.

The subject building is of historical and symbolic importance to Dublin and it was decided to maintain the current building aesthetic and elevation proportions. The design solution was predominately a fabric first approach with the focus on driving down energy loads and exploiting passive heating, cooling, ventilation and light sources. Occupant comfort was paramount to resolving the building with a delicate balance necessary to maintain optimum temperatures in a 75% glazed building. The study explored solutions offering 'optimal' load reductions with a focus on comfort as well as energy


The total Delivered Energy demand for the building can be reduced by 85%, Primary Energy demand by 80%, annual space heating demand by 95% and comfort conditions maintained without the need for air conditioning.




3D Ariel View of existing Liberty Tower Building





EXISTING SUN SHADOW STUDY











September 9 at 16:00



fRSI & Surface Temps

Nov Dec Jan Feb Mar Apr May Jun Jul Aug Sep

Saturation press Partial pressure

0.02 0.04 0.06 0.08 0.10 0.12 0.14 0.16 0.18 0.20 0.22 0

Results

 $\Psi = 1.55 \text{ W/mK}$

Linear Thermal Bridging

0.30 m²K/V

ss 0 2400 m

Thickn. lambda Q R [m] [W/(mK)] 🛐 [m²K/W

1.000 D




STITUTE OF TEC

 $D \cdot I \cdot T$

November 15 at 16:00

nZEB OFFICE RETROFIT STRATEGY



David Keogh

DT774b PG Dip DAER


D13124798

Semester 2


Office Project


1. FABRIC AND GLAZING UPGRADES (PASIVHAUS ENERPHIT STANDARD):

Fabric Element	Existing	Retrofit 0.15 (W/m ² k)	
External Wall U-Value	3.3 (W/m²k)		
Window U-Value (Ug)	5.8 (W/m²k)	0.8 (W/m ² k)	
Spandrel Panel U-Value	2.3 (W/m ² k)	0.8 (W/m ² k)	
Airtightness (Infiltration Rate)	10 ac/h at 50 Pa	1 ac/h at 50 Pa	




Fabric and Ventilation - Block 1










530,820	and a state	1947,43 2007 13,47,000 1447. 94597	INNUAL	1996038209 10		Sector 15	11 mar	West		
177 July 1977 State		Space Heating	DHW	Aux Energy	Total DE	Total PE	Hours + 25°C	Hours + 28°C		
35.2	36.6	116.0	4.2	0.0	192.0	301.9	8.0%	1.6%	Insulated spandre	
22.1	5.0	5.1	1.4	3.2	36.8	79.0	1.6%	0.0%		
37%	88%	96%	67%	N/A	80%	74%	81%	100%	Fixed lower w	
2 197 8	SIMULATIC	ON RESULT	S: AVER	AGE LOA	DS - W/n	n ²				
			Service of the servic		DHW			Total Loads	Silicone mastic seal	
11	1.2	11.7	37.0		1.3	0.0 61.3		61.3	Polyester powc flashing wit Continuous 0.7mm thi	
7	.1	1.6	1.6		0.4	1.0		11.7	Continuous 0.7mm ti	
3	7%	88%	96%		67%	N/A 80%		80%	Windows supported block	
	HEAT GAI	NS (SUMN	IER DES	IGN WEE	K) - W/m	2			Exposed cor Stone claddir	
	A STATE OF A	Lighting Gains	2010 000000000	NY STAT	Solar Gains		10.0	Total Gains	Ventilated o	
1	1.2	11.2	4.5	5	52.0	2.2	h.	81.2	Thermal bridge fr fixings	
	7.0	0.6	4.5	5	15.7	0.0		27.8	300mm Foam-glass conc	
3	8%	95%	0%		70%	100%		80%	Air-tic	
lation Res	ults - Annı	ual Energy	/ Use, Lo	oads & F	leat Gain	S				
Radiant Te	mperature .	 Operative Tem 	iperature	Outside I	Dry-Bulb Tempe	rature	24	.5 C		
~			7		\int	V		$\overline{\mathcal{A}}$	Z	
	Room Electricity 35.2 22.1 37% Ro Elect 11 7 3 3 8 11 6 11 6 11 6 11 6 11 11 11 11 11 11 1	RoomLighting Electricity35.236.622.15.037%88%SIMULATIONRoom11.211.27.137%37%HEAT GAIEquipment Gains11.27.038%38%	Room Lighting Space Electricity Electricity Heating 35.2 36.6 116.0 22.1 5.0 5.1 37% 88% 96% SIMULATION RESULT Room Lighting Electricity Electricity 11.2 11.7 7.1 1.6 37% 88% 48% 88% 11.2 11.7 637% 88% Equipment Lighting Gains Gains 11.2 11.2 11.2 11.2 11.2 11.2 37% 88% Second Gains 63ins 6ains 63ins 95%	Room Lighting Space Electricity Electricity Heating DHW 35.2 36.6 116.0 4.2 22.1 5.0 5.1 1.4 37% 88% 96% 67% SIMULATION RESULTS Room Lighting Space Electricity Electricity Heat 11.2 11.7 37 37% 88% 96% 11.2 11.7 37 37% 88% 96 201.2 1.1.7 37 37% 88% 96 37% 88% 96 11.2 11.7 37 37% 88% 96 Equipment Lighting Occup Gains Gains Gains 38% 95% 09 A 38% 95%	Room Lighting Space Aux Electricity Electricity Heating DHW Energy 35.2 36.6 116.0 4.2 0.0 22.1 5.0 5.1 1.4 3.2 37% 88% 96% 67% N/A SIMULATION RESULTS SUPPORT Room Lighting Space Heating 11.2 11.7 37.0 4 11.2 11.6 1.6 1.6 37% 88% 96% 96% 4 11.2 11.6 1.6 1.6 37% 88% 96% 4 Lighting Occupancy 6ains Gains Gains 6 11.2 11.2 4.5 1 11.2 11.2 4.5 3 38% 95% 0% 4	Room Lighting Space Aux Total 35.2 36.6 116.0 4.2 0.0 192.0 22.1 5.0 5.1 1.4 3.2 36.8 37% 88% 96% 67% N/A 80% SIMULATION RESULTS: AVERAGE LOADED Room Lighting Space Room Lighting Space DHW 11.2 11.7 37.0 1.3 7.1 1.6 1.6 0.4 37% 88% 96% 67% 488% 96% 67% 1.3 7.1 1.6 1.6 0.4 37% 88% 96% 67% Lighting Occuparcy Solar Gains Gains Gains Gains 11.2 11.2 4.5 52.0 7.0 0.6 4.5 15.7 38% 95% 0% 70%	Electricity Electricity Heating DHW Energy DE PE 35.2 36.6 116.0 4.2 0.0 192.0 301.9 22.1 5.0 5.1 1.4 3.2 36.8 79.0 37% 88% 96% 67% N/A 80% 74% SIMULATION RESULTS: AVERAGE LOADS - W/m2 Room Lighting Space Aux Electricity Electricity Heating DHW Energy 11.2 11.7 37.0 1.3 0.0 7.1 1.6 1.6 0.4 1.0 37% 88% 96% 67% N/A Equipment Lighting Occupancy Solar Heating Gains Gains Gains Gains Gains Gains Gains 11.2 11.2 4.5 52.0 2.2 2.2 7.0 0.6 4.5 15.7 0.0 38%	Room Lighting Space Aux Total Total Hours Electricity Electricity Heating DHW Energy DE PE + 25°C 35.2 36.6 116.0 4.2 0.0 192.0 301.9 8.0% 22.1 5.0 5.1 1.4 3.2 36.8 79.0 1.6% 37% 88% 96% 67% N/A 80% 74% 81% SIMULATION RESULTS AVERAGE IONALY Room Lighting Space Aux Energy Room Lighting Space Aux Energy 11.2 11.7 37.0 1.3 0.0 I 37% 88% 96% 67% N/A I 37% 88% 96% 67% N/A I 11.2 1.6 1.6 0.4 1.0 I 6ains Gains Gains Gains Gains Gains	Room Lighting Space Aux Total Total Hours Hours Electricity Electricity Heating DHW Energy DE PE +25°C +28°C 35.2 36.6 116.0 4.2 0.0 192.0 301.9 8.0% 1.6% 22.1 5.0 5.1 1.4 3.2 36.8 79.0 1.6% 0.0% 37% 88% 96% 67% N/A 80% 74% 81% 100% SIMULATIONERSULTS AVERAGE LOADS - W/m² Room Lighting Space Aux Total Electricity Electricity Heating DHW Energy Loads 11.2 11.7 37.0 1.3 0.0 61.3 7.1 1.6 1.6 0.4 1.0 11.7 37% 88% 96% 67% N/A 80% Equipment Lighting Occupancy Solar Gains	



Passive Heating Strategy (Winter): (1) Airtight and super insulated building to minimise heat losses (2) Thermal mass stores passive heat gains which helps reduce the preheat demand from the heating system (3) High glazing ratio and no external shading maximise solar gains (4) Space heating mainly from passive internal gains from occupants, lighting, equipment and solar (5) Supplemented when required by heating system and delivered by low temperature hot water radiators (6) MVHR system supplies constant fresh air at low level based on occupant demand, warmed via a heat exchanger by the extract air, with CO² monitoring and control (7) Ceiling mounted extract ducts return air to the MVHR units on each floor

